

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Abernethy Elementary School	Cafeteria		2/11/12		1	7					
Abernethy Elementary School	Gym Left		2/11/12		2						
Abernethy Elementary School	Gym Right		2/11/12		1	1					
Abernethy Elementary School	Rm 1		2/11/12	Chicago sink drinker	2	1					
Abernethy Elementary School	Rm 13		2/11/12		7	2					
Abernethy Elementary School	Rm 14		2/11/12		6	1					
Abernethy Elementary School	Rm 16		2/11/12	Chicago sink drinker	44		x	x	filter installed		
Abernethy Elementary School	Rm 16		7/18/12	Chicago sink drinker			11 x				
Abernethy Elementary School	Rm 17		2/11/12	Chicago sink drinker	21		x	x	filter installed		
Abernethy Elementary School	Rm 17		7/18/12	Chicago sink drinker			3 x				
Abernethy Elementary School	Rm 18		2/11/12	Chicago sink drinker	6		2				
Abernethy Elementary School	Rm 3		2/11/12	Chicago sink drinker	7		x				
Abernethy Elementary School	Rm 3		7/18/12	Chicago sink drinker			19 x	x	filter installed		
Abernethy Elementary School	Rm 5		2/11/12	Chicago sink drinker	5						
Abernethy Elementary School	Rm 5		7/18/12	Chicago sink drinker			4				
Abernethy Elementary School	Teachers Lounge		2/11/12	sink	17		x	x	filter installed		
Ainsworth Elementary School	A1		1/5/12	Haws sink drinker	9		3				
Ainsworth Elementary School	Near Rm 8		1/5/12	Elkay single bubbler	3		0				
Ainsworth Elementary School	Outside east		1/5/12		2		0				
Ainsworth Elementary School	Outside west		1/5/12	Elkay single bubbler	0		1				
Ainsworth Elementary School	Panda Rm		1/5/12	Haws single bubbler	1		0				
Ainsworth Elementary School	Panda Rm		1/5/12	Sink fixture	2						
Ainsworth Elementary School	Panda room		1/5/12	Haws single bubbler	1		0				
Ainsworth Elementary School	Rm 5		1/5/12	Chicago sink drinker	3		3				
Ainsworth Elementary School	Rm 6		1/5/12	Chicago sink drinker	0		0				
Ainsworth Elementary School	Teachers Rm		1/5/12	Haws sink drinker	32		14	x	filter installed		
Alameda Elementary School	Cafeteria		12/4/11		4		0				
Alameda Elementary School	Kitchen		12/4/11	Food prep sink	0		2				
Alameda Elementary School	Kitchen		12/4/11	Handwash sink	3		0				
Alameda Elementary School	Near 148		7/18/12	Single bubbler			0				
Alameda Elementary School	Near library left		12/4/11	Central double bubbler	0						
Alameda Elementary School	Near library right		12/4/11	Central double bubbler	0		0				
Alameda Elementary School	Near Rm 201		7/18/12	Halsey Taylor single bubbler	46			x	filter installed		
Alameda Elementary School	Near room 117		12/4/11	Central double bubbler	0		0				
Alameda Elementary School	Near Room 128		12/4/11		6						
Alameda Elementary School	Near Room 133		12/4/11				0				
Alameda Elementary School	Near room 140 right		12/4/11		0		0				
Alameda Elementary School	Rm 107		7/18/12	Standard single bubbler	7						
Alameda Elementary School	Rm 110		7/18/12	Chicago sink drinker	8						
Alameda Elementary School	Rm 111		7/18/12	Standard single bubbler	3						
Alameda Elementary School	Rm 115		7/18/12	Haws single bubbler	3						
Alameda Elementary School	Rm 139		7/18/12	Haws sink drinker	6						
Alameda Elementary School	Room 103		12/4/11		4		0				
Alameda Elementary School	Room 201		12/4/11		2		0				
Alameda Elementary School	Room 202		12/4/11		3		1				
Alameda Elementary School	Staff lounge		12/4/11		5		3				
Alliance High School at MEEK	Near Room 106 Left		5/11/12	Elkay single bubbler	42		3	x	filter installed		
Alliance High School at MEEK	Room 110B		6/11/12	Chicago sink drinker	5		0				
Applegate Elementary School	Near Room 3		6/17/12	Elkay single bubbler	0						
Applegate Elementary School	Near Room 7		6/17/12		0						
Applegate Elementary School	Room 12		5/20/12	Chicago sink drinker	18			x		x	no filter - field verified
Arleta Elementary School	Across from Rm 7		2/7/12		24		5	x	fixture replaced, filter installed 10/1/2001		
Arleta Elementary School	Across from Rm 8		2/7/12		15		4				

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
			2/7/12								
Arleta Elementary School	Cafeteria				16	11		x			fixture replaced, filter installed outside café (10/1/2001) same location?
Arleta Elementary School	Library		2/7/12		10	3					
Arleta Elementary School	Rm 34		2/7/12		4	12					
Arleta Elementary School	Rm 36		2/11/12	Central single bubbler	7	6					
Arleta Elementary School	Room 32		2/5/12	Central single bubbler	3	16		x			filter installed
Arleta Elementary School	Room 33		2/5/12	Central single bubbler	6	12					
Arleta Elementary School	Room 35		2/5/12	Central single bubbler	8	10					
Astor Elementary School	Across from Rm 40		11/29/11	sexauer single bubbler	5	1					
Astor Elementary School	Café		9/9/04	Central single bubbler	4	0					
Astor Elementary School	Gym		9/9/04	Haws in-wall fountain	3	0					
Astor Elementary School	Hall by Room 12		9/9/04	Central single bubbler	4	0					
Astor Elementary School	Hall by Room 34		9/9/04	Central single bubbler	5	0					
Astor Elementary School	Hall by Room 49		9/9/04	Central double bubbler	2	0					
Astor Elementary School	Near Rm 23 Left		4/8/12	Elkay double bubbler	0						
Astor Elementary School	Near Rm 23 Right		4/8/12	Elkay double bubbler	5						
Astor Elementary School	Near Rm 40		4/8/12	sexauer single bubbler	4						
Astor Elementary School	Rm 14		4/8/12	Central single bubbler	5						
Astor Elementary School	Rm 23		4/8/12	sexauer single bubbler	44			x			fixture replaces, filter installed 1/11/02
Astor Elementary School	Rm 24		4/8/12	Central single bubbler	3						
Astor Elementary School	Rm 6		4/8/12	sexauer single bubbler	2		x				
Astor Elementary School	Rm 7		4/8/12	sexauere single bubbler	31			x			fixture replaces, filter installed 1/11/02
Astor Elementary School	Rm 8		4/8/12	sexauere single bubbler	1						
Astor Elementary School	Rm 9		4/8/12	sexauer single bubbler	2						
Astor Elementary School	Room 18		9/9/04	Central sink drinker	4	0					
Astor Elementary School	Room 19		9/9/04	Central sink drinker	2	0					
Astor Elementary School	Room 20		9/9/04	Central sink drinker	3	0					
Astor Elementary School	Room 21		9/9/04	Central sink drinker	5	0					
Astor Elementary School	Room 23		9/9/04	Central single bubbler	9	0					
Astor Elementary School	Room 32		9/9/04	Central sink drinker	4	0					
Astor Elementary School	Room 33		9/9/04	Central sink drinker	4	0					
Astor Elementary School	Room 34		9/9/04	Central sink drinker	4	0					
Astor Elementary School	Room 36		9/9/04	Central sink drinker	3	0					
Astor Elementary School	Room 48		9/9/04	Central sink drinker	8	0					
Astor Elementary School	Room 49		9/9/04	Central sink drinker	3	0					
Astor Elementary School	Room 50		9/9/04	Central sink drinker	2	0					
			9/9/04								
Astor Elementary School	Room 6			Central single bubbler	24	0	x	x			fixture replaces, filter installed 1/11/02
Astor Elementary School	Room 7		9/9/04	Central single bubbler	3	0					
Astor Elementary School	Room 8		9/9/04	Central single bubbler	3	0					
Astor Elementary School	Room 9		9/9/04	Central single bubbler	4	0					
Atkinson Elementary School	125 Left		9/9/04	Chicago double bubbler	0	0					
Atkinson Elementary School	125 Right		9/9/04	Chicago double bubbler	1	0					
Atkinson Elementary School	Café North Wall		9/9/04		8	0					
Atkinson Elementary School	Cafeteria south		2/12/12	Elkay single bubbler	2						
Atkinson Elementary School	Rm 119		2/12/12	Central single bubbler	5						
Atkinson Elementary School	Room 12		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 100		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 101		9/9/04	Central single bubbler	4	0					
Atkinson Elementary School	Room 103		9/9/04		3	0					
Atkinson Elementary School	Room 104		9/9/04	Central single bubbler	2	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Atkinson Elementary School	Room 105		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 106		9/9/04	Central single bubbler	4	0					
Atkinson Elementary School	Room 107		9/9/04	Central single bubbler	1	0					
Atkinson Elementary School	Room 108		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 109		9/9/04	Central single bubbler	1	0					
Atkinson Elementary School	Room 110		9/9/04	Central single bubbler	1	0					
Atkinson Elementary School	Room 111		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 112		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 113		9/9/04	Central single bubbler	1	0					
Atkinson Elementary School	Room 114		9/9/04	Central single bubbler	1	0					
Atkinson Elementary School	Room 115		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 116		9/9/04	Central single bubbler	2	0					
Atkinson Elementary School	Room 120		9/9/04	Central single bubbler	1	0					
Beach Elementary School	A12		3/12/12	Central single bubbler	3	1					
Beach Elementary School	A3		3/12/12	Standard single bubbler	7	5					
Beach Elementary School	A4		3/12/12	Chicago sink drinker	2	0					
Beach Elementary School	Near Rm 114		3/12/12	Central single bubbler	2	0					
Beach Elementary School	P1		3/12/12	Central sink drinker	3	0					
Beach Elementary School	P2		3/12/12	Haws sink drinker	21	10		x	filter installed		
Beach Elementary School	P3		3/12/12	Chicago sink drinker	0	0					
Beaumont Middle School	Across from 23A		3/24/12	Standard single bubbler	1	1					
Beaumont Middle School	Cafeteria		3/24/12	Standard single bubbler	2	1					
Beaumont Middle School	East gym south fountain		3/24/12	in-wall fountain	9	7					
Beaumont Middle School	Near Rm 109		3/24/12	Halsey Taylor single bubbler	0	1					
Beaumont Middle School	Near Rm 140		3/24/12	Central double bubbler	11	4					
Beaumont Middle School	Near Rm 210 - filter present		3/24/12	Halsey Taylor single bubbler	1						
Beaumont Middle School	West Gym		3/24/12	Haws in-wall fountain	1	1					
Benson High School	C111		5/28/12	Elkay single bubbler	0	0					
Benson High School	C112		5/28/12	Elkay single bubbler	0	0					
Benson High School	C122		5/28/12	Elkay single bubbler	0	0					
Benson High School	C139		5/28/12	Elkay single bubbler	0	0					
Benson High School	C149		5/28/12	Elkay single bubbler	0	0					
Benson High School	Cafeteria		5/28/12	Elkay single bubbler	0	0					
Benson High School	D140		5/28/12	Central single bubbler	1						
Benson High School	D140		6/17/12	Central single bubbler	1	1					
Benson High School	E102		6/17/12	Elkay single bubbler	0	0					
Benson High School	E103		5/28/12	Haws sink drinker	7	3					
Benson High School	E105		5/28/12	Elkay single bubbler	0	0					
Benson High School	E110		6/17/12	Elkay single bubbler	0	0					
Benson High School	E116		6/17/12	sexauer single bubbler	2	0					
Benson High School	E123		6/17/12	Central sink drinker	1	1					
Benson High School	E127		6/17/12	Central sink drinker	1	0					
Benson High School	E131		6/17/12	Central sink drinker	1	0					
Benson High School	E136		5/28/12	Central sink drinker	0	0					
Benson High School	E148		6/17/12	Haws single bubbler	2	1					
Benson High School	E149		5/28/12	Elkay single bubbler	0	0					
Benson High School	Girls locker room		6/24/12	Central single bubbler	0	0					
Benson High School	Near F102		5/28/12	Central single bubbler	10	3					
Benson High School	Near G109		6/24/12	Elkay single bubbler	0	0					
Benson High School	Near girls locker room		6/24/12	Elkay single bubbler	8	14					
Benson High School	Near Room 117		5/28/12	Elkay single bubbler	0	0					
Benson High School	Near Room 211		5/28/12	Elkay single bubbler	0	0					
Benson High School	Near Room 222		5/28/12	Elkay single bubbler	0	0					
Benson High School	Near training room		6/24/12	Haws in-wall fountain	3	1					
Benson High School	North mens locker room		6/24/12	In-wall fountain	2	0					
Benson High School	North of weight room		6/24/12	Haws in-wall fountain	4	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Benson High School	Outside cafeteria		5/28/12	Central double bubbler	0	0					
Benson High School	Radio station		6/24/12	Single bubbler	0	0					
Benson High School	Room 236		5/28/12	Chicago sink drinker	7	2					
Benson High School	West gym		6/24/12	Double fountain	2	1					
Benson High School	West mens locker room		6/24/12	Haws in-wall fountain	3	2					
Benson High School	West of auditorium		5/28/12	Halsey Taylor double bubbler	2	0					
BESC	By music shop		7/2/12	Elkay single cooler	3	4					
BESC	Carpenter shop		7/2/12	Sunroc cooler	5	7					
BESC	First floor by elevator - left		7/2/12	Elkay single cooler	0	1					
BESC	Human Resources office		7/2/12	Elkay single cooler	2	2					
BESC	IT room		7/2/12	Elkay single cooler	0	0					
BESC	Near 150		7/2/12	Elkay single cooler	0	0					
BESC	Near 260		7/2/12	Elkay single cooler	0	0					
BESC	Near 270		7/2/12	Elkay single cooler	2	4					
BESC	Near L1-60		7/2/12	EZ H2O	0						
BESC	Near L2-29		7/2/12	Elkay single cooler	0	0					
BESC	Near maintenance office		7/2/12	Elkay single cooler	2	2					
BESC	Plumbing shop		7/2/12	unmarked cooler	0	0					
BESC	Warehouse		7/2/12	Elkay single cooler	6	7					
Beverly Cleary at Fernwood	210C		3/24/12	Central sink drinker	13	2					
Beverly Cleary at Fernwood	East Gym		3/24/12		0	0					
Beverly Cleary at Fernwood	Rm 139 North		3/24/12	Chicago sink drinker	2	1					
Beverly Cleary at Fernwood	Rm 139 South		3/24/12	Chicago sink drinker	2	0					
Beverly Cleary at Fernwood	West Gym		3/24/12	In-wall fountain	1	0					
Boise-Eliot Elementary School	Near 211 right fixture		7/8/12	Central double bubbler		0					
Boise-Eliot Elementary School	Near Rm 211		3/11/12	Central double bubbler	0						
Boise-Eliot Elementary School	Rm 102		7/8/12	Chicago sink drinker		2					
Boise-Eliot Elementary School	Rm 104		3/11/12	chicago sink drinker	3						
Boise-Eliot Elementary School	Rm 104		7/8/12	Single bubbler		2					
Boise-Eliot Elementary School	Rm 201		7/8/12	Chicago sink drinker	4	0					
Bridger Elementary School	Portable 2		2/27/12	Haws sink drinker	14	2					
Bridger Elementary School	Portable 3		2/27/12	Haws sink drinker	1	0					
Bridger Elementary School	Portable 4		2/27/12	Haws sink drinker	1	0					
Bridger Elementary School	Rm 10		2/25/12	Central single bubbler	0	0					
Bridger Elementary School	Rm 7		2/27/12	Chicago sink drinker	6						
Bridlemile Elementary School	Gym		6/23/12	Sexauer in wall	15	0					
Bridlemile Elementary School	Portable		6/23/12	Chicago sink drinker	46	15		x	filter installed		
Buckman Elementary School	Near Rm 103 Left		2/18/12	Elkay double bubbler	0	0					
Buckman Elementary School	Near Rm 103 Right		2/18/12	Elkay double bubbler	2						
Buckman Elementary School	Pool area left		7/15/12	Elkay single bubbler	2	2					
Buckman Elementary School	Pool area right		7/15/12	Elkay single bubbler	1	2					
Buckman Elementary School	Rm 100 - low pressure		2/18/12	Chicago sink drinker	5	2					
Buckman Elementary School	Rm 101		2/18/12	Central sink drinker	15	3					
Buckman Elementary School	Rm 114		2/18/12	Chicago sink drinker	4	1					
Buckman Elementary School	Rm 208		2/18/12	Chicago sink drinker	23	11		x	filter installed		
Capitol Hill Elementary School	East cafeteria		1/29/12	kohler in wall	49	8		x	filter installed		
Capitol Hill Elementary School	West Cafeteria		1/29/12	kohler in wall	30	16		x	filter installed		
Cesar Chavez School	Across from Rm 128 Water dispenser		2/1/12	Elkay single bubbler	0						
Cesar Chavez School	Across from Rm 204		12/27/11		4	0					
Cesar Chavez School	Girls locker room		12/27/11		3	0					
Cesar Chavez School	Outside gym east		12/27/11	Haws double bubbler	2						
Cesar Chavez School	Room 135		12/27/11		8	2					
Cesar Chavez School	Room 136		12/27/11	Chicago sink drinker	5	1					
Cesar Chavez School	Room 171		12/27/11	Chicago sink drinker	5	1					
Chapman Elementary School	7B		1/21/12	Chicago sink drinker	2						
Chapman Elementary School	Music Rm		1/21/12	Chicago sink drinker	4						

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Chapman Elementary School	Near rm 1 Right		1/21/12	Elkay double bubbler	13	1					
Chapman Elementary School	Rm 10		1/21/12		1						
Chapman Elementary School	Rm 22		1/21/12	Chicago sink drinker	2	1					
Chapman Elementary School	Rm 23		1/21/12	Chicago sink drinker	4	4					
Chapman Elementary School	Rm 26		1/21/12	unmarked	18	7		x	filter installed		
Chief Joseph Elementary School	Cafeteria		4/8/12	elkay in-wall fountain	2						
Chief Joseph Elementary School	Near 16		7/18/12	Elkay single bubbler	12	370		x	filter installed		
Chief Joseph Elementary School	Rm 1		7/18/12	Elkay single bubbler	4						
Chief Joseph Elementary School	Rm 26		7/18/12	Chicago sink drinker	5						
Chief Joseph Elementary School	Rm 27		7/18/12	Chicago sink drinker	5						
Chief Joseph Elementary School	Rm 28		7/18/12	Haws sink drinker	16			x	filter installed		
Chief Joseph Elementary School	Rm 6		4/8/12	Standard single bubbler	6	3					
Chief Joseph Elementary School	Rm 8		4/8/12	Standard single bubbler	4						
Chief Joseph Elementary School	Rm 8		7/18/12	Standard single bubbler	31	67		x	filter installed		
Child Services Center	3rd floor SE hallway		7/14/12	Elkay single bubbler	5	0					
Child Services Center	Near 13		7/14/12	Standard single bubbler	25	21		x	filter installed		
Cleveland High School	Cafeteria left		1/22/12	Central double bubbler	9	3					
Cleveland High School	Cafeteria right		1/22/12	Central double bubbler	17			x	filter installed		
Cleveland High School	Near 217		1/22/12	Halsey Taylor single bubbler	21			x	filter installed		
Cleveland High School	Near rm 133		1/22/12		1						
Cleveland High School	Near Rm 333		1/22/12	Central double bubbler	59	34		x	filter installed		
Cleveland High School	Near Rm 366		1/22/12	Central single bubbler	9	9					
Cleveland High School	Near rm 380		1/22/12	Central single bubbler	8	0					
Cleveland High School	Outside gym, north fountain - filter		6/24/12	sexauer single bubbler	3						
Cleveland High School	Outside gym, south fountain - filter		6/24/12	sexauer single bubbler	6						
Cleveland High School	West boys locker room (main building)		2/20/12	Haws single bubbler	18	23		x	filter installed		
Columbia Site	Ground floor, SE corner bathroom		7/7/12	Crane in-wall fountain	570	40		x	filter installed		
Columbia Site	Gym - east		7/7/12	Central single bubbler	22	15		x	filter installed		
Columbia Site	Gym - west		7/7/12	Single bubbler	3	6					
Columbia Site	Near 36 - filter		7/7/12	Elkay single bubbler	4						
Columbia Site	Near Rm 9		7/7/12	Elkay single bubbler	17	6		x	filter installed		
Creative Sciences School	Hall near Rm 4 - filter		7/14/12	sexauer in wall	4	2					
Creative Sciences School	Rm 10 - Headstart		7/14/12	Central sink drinker	11	4					
Creative Sciences School	Rm 11		7/14/12	Central sink drinker	15	7					
Creative Sciences School	Rm 2		7/14/12	Sink drinker		19		x	filter installed		
Creative Sciences School	Rm 24		7/14/12	Sink drinker	17			x	filter installed		
Creative Sciences School	Rm 3		7/14/12	Central double bubbler	25	24		x	filter installed		
Creative Sciences School	Rm 4		7/14/12	Central sink drinker	23	18		x	filter installed		
Creative Sciences School	Rm 5		7/14/12	Sink drinker		51		x	filter installed		
Creative Sciences School	Rm 7		7/14/12	Central sink drinker	22	3		x	filter installed		
Creative Sciences School	Rm 8		7/14/12	Central sink drinker	22	8		x	filter installed		
Creston Annex (DRAC)		5	2/4/12	In-wall fountain	28	4		x	filter installed		
Creston Elementary School	100A cold water faucet	100A	4/22/16	COLD WATER FAUCET	15	11					
Creston Elementary School	100B cold water faucet	100B	4/22/16	COLD WATER FAUCET	10	52		x	signage posted, outlet disabled		
Creston Elementary School	100C cold water faucet	100C	4/22/16	COLD WATER FAUCET	10	0					
Creston Elementary School	101B cold water faucet	101B	4/22/16	COLD WATER FAUCET	0	4					
Creston Elementary School	102 Cold Water Faucet	102	4/22/16	COLD WATER FAUCET	12	3					
Creston Elementary School	103 cold water faucet	103	4/22/16	COLD WATER FAUCET	0	0					
Creston Elementary School	104 cold wate faucet	104	4/22/16	Sink fixture	7	0					
Creston Elementary School	105 cold water faucet	105	4/22/16	COLD WATER FAUCET	5	0					
Creston Elementary School	106 cold water faucet	106	4/22/16	COLD WATER FAUCET	7	2					
Creston Elementary School	107 cold water faucet	107	4/22/16	COLD WATER FAUCET	7	0					
Creston Elementary School	108 cold water faucet	108	4/22/16	COLD WATER FAUCET	6	0					
Creston Elementary School	108A cold water faucet	108A	4/22/16	COLD WATER FAUCET	26	11		x	outlet disabled		
Creston Elementary School	109 cold water faucet	109	4/22/16	COLD WATER FAUCET	9	0					
Creston Elementary School	110 cold water faucet	110	4/22/16	COLD WATER FAUCET	0	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Creston Elementary School	110 Haws Sink Drinker	110	4/22/16	Haws single bubbler	0						
Creston Elementary School	111 cold water faucet	111	4/22/16	COLD WATER FAUCET	13	8					
Creston Elementary School	111 sink fountain	111	4/22/16	Single bubbler	5						
Creston Elementary School	112 cold water faucet	112	4/22/16	COLD WATER FAUCET	0	0					
Creston Elementary School	112 cold water faucet	112	4/22/16	COLD WATER FAUCET	6	0					
Creston Elementary School	112 sink fountain	112	4/22/16	Single bubbler	2						
Creston Elementary School	113 cold water faucet	113	4/22/16	COLD WATER FAUCET	0	0					
Creston Elementary School	114 2nd sink by door cw	114	4/22/16	COLD WATER FAUCET	2	0					
Creston Elementary School	114 4th sink from door cw	114	4/22/16	COLD WATER FAUCET	11	2					
Creston Elementary School	114 5th teachers sink cw	114	4/22/16	COLD WATER FAUCET	14	4					
Creston Elementary School	114 eye wash sink cw	114	4/22/16	COLD WATER FAUCET	8	0					
Creston Elementary School	114 sink by door-cw	114	4/22/16	COLD WATER FAUCET	0	0					
Creston Elementary School	115 cold water faucet- Flushed	115	4/22/16	COLD WATER FAUCET	0	0					
Creston Elementary School	116 cold water faucet	116	4/22/16	COLD WATER FAUCET	3	3					
Creston Elementary School	116 sink fountain	116	4/22/16	Single bubbler	3						
Creston Elementary School	117 cold water faucet	117	4/22/16	COLD WATER FAUCET	5	2					
Creston Elementary School	119 Sink cold water faucet	119	4/22/16	COLD WATER FAUCET	5	6					
Creston Elementary School	Annex Rm 5		2/4/12	Elkay in wall	28	4		x	filter installed		
Creston Elementary School	Clinc 2 cold water faucet	Dental Clinic	4/22/16	COLD WATER FAUCET	0	0					
Creston Elementary School	Clinc 3 cold water faucet	Dental Clinic	4/22/16	COLD WATER FAUCET	5	0					
Creston Elementary School	Clinic 1 Cold Water Faucet	Dental Clinic	4/22/16	COLD WATER FAUCET	0	0					
Creston Elementary School	Clinic work sink cold water faucet	Dental Clinic	4/22/16	COLD WATER FAUCET	4	0					
Creston Elementary School	Dental Corner Sink Cold Water	dental Clinic	4/22/16	COLD WATER FAUCET	5	2					
Creston Elementary School	Gym- NW Corner Fountain	Gym NW	3/22/16		3						
Creston Elementary School	Gym- SE Corner Fountain	Gym SE	3/22/16	Large wall fountain	9						
Creston Elementary School	Hall fountain by 102	hall by 102	4/22/16	fountain bubbler	2						
Creston Elementary School	Hall fountain by 103	hall by 103	4/22/16	Single bubbler	0						
Creston Elementary School	hall fountain by 107	hall fountain by 107	4/22/16	Single bubbler	3						
Creston Elementary School	hall fountain by 116	hall fountain by 116	4/22/16	Single bubbler	6						
Creston Elementary School	Hall Fountain by Main Office	Hall by Main Office	4/22/16	Single bubbler	4						
Creston Elementary School	Hall fountain outside cafeteria	Cafetria Hallway	4/22/16	Central single bubbler	3						
Creston Elementary School	hall fountain by 106	hall by 106	4/22/16	Single bubbler	0						
Creston Elementary School	hall fountain by gym	hall by gym	4/22/16	Single bubbler	0	0					
Creston Elementary School	hallway fountain by 112	hall by 112	4/22/16	Single bubbler	0						
Creston Elementary School	Kitchen Food Prep Sink CW	Kitchen	3/22/16	Sink fixture	23	5	x	x	fixture replaced		
Creston Elementary School	Kitchen Sprayer Sink	Kitchen	4/22/16	COLD WATER FAUCET	6	0					
Creston Elementary School	Kitchen work Sink	Kitchen	4/22/16	COLD WATER FAUCET	3	2					
Creston Elementary School	Kitchen work Sink Water Filler Faucet	Kitchen	4/22/16	COLD WATER FAUCET	13	0					
Creston Elementary School	Library office cold water faucet	library office	4/22/16	COLD WATER FAUCET	29	4	x	x	fixture replaced		
Creston Elementary School	Near office		2/4/12	Elkay single bubbler	7	3					
Creston Elementary School	Near Rm 107		2/4/12	Central single bubbler	2	0					
Creston Elementary School	Nurses Office Cold Water Faucet	Nurses Office	4/22/16	COLD WATER FAUCET	3	6					
Creston Elementary School	Nurses office sink faucet	Nurses Office	4/22/16	COLD WATER FAUCET	3	6					
Creston Elementary School	Room 101	101	3/22/16	Sink fixture	18	16	x	x	fixture replaced		
Creston Elementary School	Room 101C		4/22/12	Central single bubbler	2	1					
Creston Elementary School	Room 111	111	3/22/16	Chicago single bubbler	33	0	x	x	fixture replaced		
Creston Elementary School	Room 113	113	3/22/16	Chicago single bubbler	8						
Creston Elementary School	Room 114	114	3/22/16	Sink faucet for washing	14	11					
Creston Elementary School	Room 115	115	3/22/16	Haws single bubbler	4						
Creston Elementary School	Room 117	117	3/22/16	Haws single bubbler	6						
Creston Elementary School	Room 118	118	3/22/16	Sink fixture	5	4					
Creston Elementary School	Spray Sink Water Fill Faucet	Kitchen	4/22/16	COLD WATER FAUCET	24	6	x	x	fixture replaced		
DaVinci Arts Middle School	DaVinci- Portable F	Portlabd F	12/10/14	COLD WATER FAUCET	5	5					
DaVinci Arts Middle School	East of balcony third floor		7/7/12	Elkay single bubbler	8	2					
DaVinci Arts Middle School	Faucet #1	107	1/9/15	COLD WATER FAUCET	18	3		x	signage posted, Teacher, students informed		
DaVinci Arts Middle School	Faucet #2	107	1/9/15	COLD WATER FAUCET	15	4					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
DaVinci Arts Middle School	Faucet #3	107	1/9/15	COLD WATER FAUCET	10	0					
DaVinci Arts Middle School	Faucet #4	107	1/9/15	COLD WATER FAUCET	20	12		x	signage posted, Teacher, students informed		
DaVinci Arts Middle School	Hall Fountain by Library	Library Hall	1/23/15	Elkay single bubbler	15	0					
DaVinci Arts Middle School	Hall Fountain by 102		1/23/15	Central double bubbler	0						
DaVinci Arts Middle School	Hall Fountain by 106		1/23/15	Elkay single bubbler	8						
DaVinci Arts Middle School	Hall Fountain by 106	106	1/23/15	Elkay single bubbler	7						
DaVinci Arts Middle School	Hall Fountain by 110		1/23/15	Central double bubbler	2						
DaVinci Arts Middle School	Hall Fountain by 202		1/23/15	Central double bubbler	0						
DaVinci Arts Middle School	Hall Fountain by 204		1/23/15	Central double bubbler	0	0					
DaVinci Arts Middle School	Hall Fountain by 301		1/23/15	Central double bubbler	3	0					
DaVinci Arts Middle School	Hall Fountain by 307	307	1/23/15	Elkay single bubbler	0						
DaVinci Arts Middle School	Hall Fountain by Elevator	Elevator	1/23/15	Central double bubbler	6						
DaVinci Arts Middle School	Hall Fountain by room 104		1/23/15	Central double bubbler	0						
DaVinci Arts Middle School	Hall Fountain by room 211	211	1/23/15	Chicago double bubbler	6						
DaVinci Arts Middle School	Near elevator third floor - filter		7/7/12	Elkay double bubbler	6						
DaVinci Arts Middle School	Near room 206		3/5/12			4					
DaVinci Arts Middle School	Near Room 211		3/5/12	Central double bubbler	8	2					
DaVinci Arts Middle School	Near Room 302		6/10/12		7	14					
DaVinci Arts Middle School	Porttable A	Portable A	12/10/14	Central single bubbler	9	0					
DaVinci Arts Middle School	Porttable F	Porttable F	12/10/14	COLD WATER FAUCET	0						
DaVinci Arts Middle School		Portable A	12/10/14	COLD WATER FAUCET	0	0					
De La Salle (formerly Kenton)	Near counseling center - basement		5/13/12	Central double bubbler	4	1					
De La Salle (formerly Kenton)	Near Room 106		5/13/12	Central single bubbler	1	0					
De La Salle (formerly Kenton)	Near storage room - filter		5/13/12	Elkay double bubbler	1						
De La Salle (formerly Kenton)	South of office ground floor		5/13/12	Halsey Taylor single bubbler	3	5					
Duniway Elementary School	Hall by Room 1		3/18/10	Central single bubbler	0	0					
Duniway Elementary School	Hall by Room 12		2/12/10	Haws double bubbler	0	0					
Duniway Elementary School	Hall by Room 12		2/12/10	Haws double bubbler	12	0					
Duniway Elementary School	Hall by Room 19		2/12/10	Central single bubbler	31	26		x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Hall by Room 19		3/18/10	Central double bubbler	21			x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Hall by Room 19		5/13/10	Central double bubbler	51	50		x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Kitchen		2/12/10	COLD WATER FAUCET	2	0					
Duniway Elementary School	Kitchen		2/12/10	Wash sink	2	0					
Duniway Elementary School	Near Rm 1		2/12/10	Central single bubbler	16	15		x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Nurses Restroom		2/12/10	Wash sink	6	2					
Duniway Elementary School	Room 1		2/12/10	central	18	12	x	x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Room 1		3/18/10	central	0		x				
Duniway Elementary School	Room 2		2/12/10	central	2	0					
Duniway Elementary School	Room 3		2/12/10	chicago	0	0					
Duniway Elementary School	Room 4		2/12/10	central	0	0					
Duniway Elementary School	Room 5		2/12/10	central	0	0					
Duniway Elementary School	Room 6		2/12/10	central	3	3					
Duniway Elementary School	Teacher's Lounge Upstairs		2/12/10	Sink for drinking	34	2	x	x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Teacher's Lounge Upstairs		3/18/10	Sink fixture	14	6	x				
Duniway Elementary School			2/12/10								
Edwards Elementary School	East Office		4/22/12	elkay sink drinker	2	16		x	fixture replaces, filter installed		
Edwards Elementary School	Near Room 3		4/22/12	Elkay single bubbler	12	2					
Edwards Elementary School	Near Room 5		4/22/12	sexauer in wall fountain	3	0					
Faubion Elementary School	Café South		9/9/04		0	0					
Faubion Elementary School	East Cafeteria		4/29/12	sexauer single bubbler	3						
Faubion Elementary School	Gym		9/9/04	Haws in-wall fountain	6	0					
Faubion Elementary School	Hall by café		9/9/04	Halsey Taylor single bubbler	0	0					
Faubion Elementary School	Hall by Room 9		9/9/04	Standard single bubbler	0	0					
Faubion Elementary School	North cafeteria		9/9/04	Standard single bubbler	22	0	x	x			
Faubion Elementary School	North cafeteria		4/29/12	sexauer single bubbler	1		x				
Faubion Elementary School	Room 1		9/9/04	Halsey Taylor single bubbler	1	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Faubion Elementary School	Room 10		9/9/04	Standard single bubbler	2	0					
Faubion Elementary School	Room 11		9/9/04	Chicago sink drinker	3	0					
Faubion Elementary School	Room 12		9/9/04	Central single bubbler	1	0					
Faubion Elementary School	Room 13		9/9/04		0	0					
Faubion Elementary School	Room 14		9/9/04	Standard single bubbler	3	0					
Faubion Elementary School	Room 15		9/9/04		1	0					
Faubion Elementary School	Room 20		9/9/04	Standard single bubbler	0	0					
Faubion Elementary School	Room 21		9/9/04	Central single bubbler	1	0					
Faubion Elementary School	Room 22		9/9/04	Standard single bubbler	4	0					
Faubion Elementary School	Room 4		9/9/04	Halsey Taylor single bubbler	3	0					
Faubion Elementary School	Room 5		9/9/04	Halsey Taylor single bubbler	4	0					
Faubion Elementary School	Room 6		9/9/04	Halsey Taylor single bubbler	6	0					
Faubion Elementary School	Room 7		9/9/04	Halsey Taylor single bubbler	3	0					
Faubion Elementary School	Room 8		9/9/04	Halsey Taylor single bubbler	1	0					
Faubion Elementary School	Room 8		4/29/12	sexauer single bubbler	4	3					
Faubion Elementary School	Room Principal2		4/29/12	Halsey Taylor single bubbler	17	3		x		x	
Forest Park Elementary School	Outside		7/16/12	Single bubbler	0	0					
Franklin High School	107A		3/11/12	Elkay single bubbler	8	15					
Franklin High School	East of auditorium		3/11/12	Central single bubbler	22	17		x	filter installed		
Franklin High School	Near Rm 173		3/11/12	Elkay single bubbler	2	0					
Franklin High School	Near Rm 239		3/11/12	Elkay single bubbler	0						
Franklin High School	Near Rm 244		3/11/12	Central single bubbler	4	5					
Franklin High School	Near Rm 31		3/11/12	Haws single bubbler	9	0					
Franklin High School	Rm 101		3/11/12	Elkay single bubbler	0	2					
Franklin High School	Rm 273		3/11/12	Thin faucet for water bottles	28	4		x		x	
George Middle School	Near Rm 105		3/31/12	Central single bubbler	1	0					
George Middle School	Rm 212		3/31/12	Chicago sink drinker	3	0					
George Middle School	Rm 303		3/31/12	Chicago sink drinker	100	24		x	filter installed		
George Middle School	Rm 413		3/31/12	Chicago sink drinker	15	1					
George Middle School	Rm 417		3/31/12	Chicago sink drinker	12						
Glencoe Elementary School	Across from Rm 102		2/19/12	Elkay single bubbler	0						
Glencoe Elementary School	Across from Rm 206		2/19/12	Elkay single bubbler	0						
Glencoe Elementary School	Rm 102		2/19/12	Chicago sink drinker	3	0					
Grant High School	Boys locker room		6/26/12	Central in-wall fountain	4	1					
Grant High School	Near girls locker room		6/26/12	Elkay single cooler	0	1					
Grant High School	Near new gym		6/26/12	Central in-wall fountain	5	1					
Grant High School	Near Room 231 Left		5/20/12	Elkay double bubbler	3	0					
Grant High School	Near Room 231 Right		5/20/12	Elkay double bubbler	6						
Grant High School	Room 31		5/20/12	Haws sink drinker	7	9					
Grant High School	Room 32		5/20/12	Haws sink drinker	32	10		x	filter installed		
Grant High School	Room 33		5/20/12	Haws sink drinker	14	5					
Grant High School	Room S12		5/20/12	Central single bubbler	5	4					
Grant High School	Weight room		6/26/12	Elkay in-wall fountain	1	3					
Gray Middle School	100		1/8/12	Chicago sink drinker	1	0					
Gray Middle School	Across from Rm 113		1/8/12	Elkay single bubbler	3	0					
Gray Middle School	Art Rm		2/7/12	Haws sink drinker	29	5		x	filter installed		
Gray Middle School	Boys locker rm		1/8/12	Elkay single bubbler	0	0					
Gray Middle School	Cafeteria		1/8/12	Elkay single bubbler	1	0					
Gray Middle School	East gym		1/8/12	Standard in-wall fountain	2	0					
Gray Middle School	Girls locker rm		1/8/12	Elkay single bubbler	1	0					
Gray Middle School	Hall Fountain by Room 100	100	10/9/03	Haws single bubbler	1	0					
Gray Middle School	Music Rm		1/16/12	Haws sink drinker	13	3					
Gray Middle School	Near cafeteria south		1/8/12	Elkay single bubbler	8	1					
Gray Middle School	Near Rm 104		1/8/12	Elkay single bubbler	0	0					
Gray Middle School	Near Rm 124		1/8/12	Elkay single bubbler	0	0					
Gray Middle School	Near Rm 126		1/8/12	elkay sink drinker	0	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Gray Middle School	North outside of Cafeteria		1/16/12	Elkay single bubbler	0	0					
Gray Middle School	Office work room		10/5/11	sink	2	0					
Gray Middle School	Rm 104		1/8/12	Chicago sink drinker	2	1					
Gray Middle School	Rm 105		1/8/12	Chicago sink drinker	0	0					
Gray Middle School	Rm 106		1/6/12	Chicago sink drinker	0	0					
Gray Middle School	Rm 107		1/8/12	Chicago sink drinker	0	0					
Gray Middle School	Rm 111		1/8/12		4	1					
Gray Middle School	Rm 112		1/8/12	Chicago sink drinker	0	0					
Gray Middle School	Rm 114		1/8/12	Chicago sink drinker	11	4					
Gray Middle School	Rm 115		1/8/12	Chicago sink drinker	1	0					
Gray Middle School	Rm 116		1/8/12	Chicago sink drinker	1	0					
Gray Middle School	Rm 117		1/8/12	Chicago sink drinker	0	0					
Gray Middle School	Rm 118		1/8/12	Chicago sink drinker	0	0					
Gray Middle School	Rm 119		1/8/12	Chicago sink drinker	2	0					
Gray Middle School	Rm 120		1/8/12	Chicago sink drinker	0	0					
Gray Middle School	Rm 121		1/8/12	Chicago sink drinker	2	0					
Gray Middle School	Rm 122		1/8/12	Chicago sink drinker	1	0					
Gray Middle School	Rm 123		1/8/12	Chicago sink drinker	1	0					
Gray Middle School	Rm 124		1/8/12	Chicago sink drinker	1	0					
Gray Middle School	Rm 125		1/8/12	elkay sink drinker	0	0					
Gray Middle School	Rm 126		1/8/12	In-wall fountain	0	0					
Gray Middle School	rm 222		2/7/12	Haws sink drinker	14	3					
Gray Middle School	Sun Room		2/7/12	Haws sink drinker	9	2					
Gray Middle School	West gym		1/8/12	Standard in-wall fountain	1	0					
Green Thumb	House Downstairs sink		9/16/04	Sink fixture	1	0					
Green Thumb	House-Upstairs Kitchen Sink		9/16/04	Sink for drinking	2	0					
Green Thumb	Portable #3 Cold Water Sink Faucet	Portable #3	9/16/04	Sink for drinking	1	0					
Green Thumb	Portable #2 Cold Water Sink Faucet	Portable #2	9/16/04	Sink for drinking	5	0					
Green Thumb	Portable 4 cold water sink faucet	Portable #4	9/16/04	Sink for drinking	3	0					
Green Thumb	Portable 4&5 fountain by Restrooms	Portable 4 and 5	9/16/04	Central single bubbler	4	0					
Green Thumb	Portable 5 Cold Water Sink Faucet	Portable #5	9/16/04	Sink for drinking	3	0					
Grout Elementary School	Near 101 Left double right fixture		2/7/12	Halsey Taylor double bubbler	1						
Grout Elementary School	Near 101Right double, elkay fixture left		2/7/12	Halsey Taylor double bubbler	1	0					
Grout Elementary School	Near library left fixture		2/7/12	Unmarked fixture	6						
Grout Elementary School	Near library right fixture		2/7/12	Halsey Taylor double bubbler	4	3					
Grout Elementary School	Near Rm 106		2/4/12		8	11					
Grout Elementary School	Near Rm 106		2/11/12	Elkay single cooler		18		x	fixture replaced, filter installed 11/19/01		
Grout Elementary School	Near Rm 111 Left		2/11/12			1					
Grout Elementary School	Near Rm 112 Right fixture of left ftn		2/1/12	Halsey Taylor double bubbler	1						
Grout Elementary School	Near Rm 201 Left		2/7/12	Halsey Taylor double bubbler	29	38		x	filter installed		
Grout Elementary School	Near Rm 201 right (central brand fixture)		2/11/12	Halsey Taylor double bubbler	24	3		x	filter installed		
Grout Elementary School	Near Rm 206 left		2/7/12	Halsey Taylor double bubbler	16	11		x	filter installed		
Grout Elementary School	Near Rm 206 Right		2/7/12	Halsey Taylor double bubbler	24	25		x	filter installed		
Grout Elementary School	Near Rm 208		2/4/12		28	4		x	filter installed		
Grout Elementary School	Near Rm 213 left (elkay fixture)		2/7/12	Halsey Taylor double bubbler	6						
Grout Elementary School	Near Rm 213 Right		2/7/12	Halsey Taylor double bubbler	7	12					
Grout Elementary School	Near Rm A left double right fixture		2/4/12		46			x	filter installed		
Grout Elementary School	Near Rm A right double left fixture		2/11/12	Halsey Taylor double bubbler		18		x	filter installed		
Grout Elementary School	Near Rm C		2/11/12	Halsey Taylor double bubbler		14					
Grout Elementary School	Near Rm C left double Left fixture		2/7/12	Central double bubbler	24			x	filter installed		
Grout Elementary School	Near Rm C left double right fixture - elkay		2/7/12		25			x	filter installed		
Grout Elementary School	Near Rm C right double left fixture		2/7/12	Halsey Taylor double bubbler	35	5		x	filter installed		
Grout Elementary School	Nr Rm A left double left fixture		2/4/12		26			x	filter installed		
Grout Elementary School	Rm 109		2/4/12		10	3					
Grout Elementary School	Rm 112		2/7/12	Chicago sink drinker	5	23		x	filter installed		
Grout Elementary School	Room 104	104	3/22/16	Sink faucet for washing	0	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Grout Elementary School	Room 104	104	3/22/16		0						
Harrison Park School	Near room 137		12/13/11	Central single bubbler	6	0					
Harrison Park School	Near Room 169		2/27/12	Elkay single bubbler		12					
Harrison Park School	North gym		12/13/11	In-wall fountain	2	6					
Harrison Park School	North gym		6/24/12	In-wall fountain	10	6					
Harrison Park School	Rm 110		4/8/12	sink faucet for drinking	8	0					
Harrison Park School	Room 107 - has filter		2/27/12	Elkay single bubbler	4						
Harrison Park School	Room 130		2/27/12	Central single bubbler	14	41		x	filter installed		
Harrison Park School	Room 149		2/27/12	Central single bubbler	13	7					
Harrison Park School	Room 169B		2/27/12	Central single bubbler	3	1					
Harrison Park School	Room 185A		12/13/11	Chicago sink drinker	2	0					
Harrison Park School	Room 188		2/27/12	Chicago sink drinker	2	0					
Harrison Park School	Room 189		2/27/12	Chicago sink drinker	3	0					
Harrison Park School	Room 197		12/13/11	Chicago sink drinker	4	0					
Harrison Park School	Room 198		12/13/11	Sink drinker	2	0					
Hayhurst Elementary School	Gym		1/28/12		11	8					
Hayhurst Elementary School	Rm 15		1/28/12		21	3		x	filter installed		
Hayhurst Elementary School	Rm 8		1/28/12		4	5					
Holladay Annex	Near office		3/10/12	Elkay double bubbler	0						
Holladay Center	Rm 1		2/25/12	Chicago sink drinker	2						
Holladay Center	Rm 14		2/25/12	Chicago sink drinker	4						
Holladay Center	Rm 4		2/25/12	Chicago sink drinker	2						
Hosford Middle School	Near Rm 207		2/19/12	Central double bubbler	4	0					
Hosford Middle School	Rm 13		2/19/12	Chicago sink drinker	1	0					
Hosford Middle School	Rm 20		2/19/12	Elkay single bubbler	2	2					
Hosford Middle School	Rm 3		2/19/12	Elkay single bubbler	0	0					
Hosford Middle School	Rm 8		2/19/12	Central sink drinker	2	0					
Hosford Middle School	Rm 9		2/19/12	Standard single bubbler	2	0					
Humboldt Elementary School	Rm 19		3/11/12	Haws sink drinker	13	10					
Humboldt Elementary School	Rm 22		3/11/12	Haws sink drinker	13	5					
Humboldt Elementary School	Rm 37		3/11/12	Haws sink drinker	4	2					
Irvington Elementary School	Rm 111		3/19/12	Halsey Taylor single bubbler	5						
Jackson Middle School	Across from A108		7/15/12		45	58		x	filter installed		
Jackson Middle School	Across from A108, left		12/2/11		5	4					
Jackson Middle School	Across from A112		12/2/11		0	0					
Jackson Middle School	Boys locker rm across from towel rm		12/2/11		5	3					
Jackson Middle School	Boys locker room, Near TM Rm A		12/2/11		1	0					
Jackson Middle School	Near D147 - filter		7/15/12	Elkay double bubbler	4	0					
Jackson Middle School	Near G east - mech		7/15/12	Central double bubbler	19	12		x		x	no filter - field verified
Jackson Middle School	Near G220 left - filter		7/15/12	Elkay double bubbler	0						
Jackson Middle School	Near G220 right - filter		7/15/12	Elkay double bubbler	0						
James John Elementary School	Across from Room 28		4/9/12	Central double bubbler	3						
James John Elementary School	Near Rm 21		4/9/12	Central double bubbler	7	2					
James John Elementary School	Near Rm 39		4/9/12	Elkay double bubbler	8	0					
James John Elementary School	Near Room 31		4/9/12	Elkay single bubbler	5						
James John Elementary School	Rm 39		4/9/12	Chicago sink drinker	4	1					
James John Elementary School	Rm 40		4/9/12	elkay sink drinker	0	0					
Jefferson High School	A11		6/22/12	chicago faucet	20	18		x	fixture replaced, filter installed 11/5/04		
Jefferson High School	A12		6/10/12	Faucet for drinking	10	34		x	filter installed		
Jefferson High School	A41		6/10/12	Central sink drinker	66	33		x	filter installed		
Jefferson High School	A42		6/10/12	Central sink drinker	18	3		x	filter installed		
Jefferson High School	A43		6/10/12	Central sink drinker	3	3					
Jefferson High School	Auto Shop		6/22/12	Elkay single cooler	37	39		x	filter installed		
Jefferson High School	Boys locker room (outside building)		6/22/12	Elkay single bubbler	26	26		x	filter installed		
Jefferson High School	East cafeteria - filter		6/10/12	Elkay single bubbler	3						
Jefferson High School	Girls locker room (outside building)		6/22/12	Kohler single bubbler	64	57		x	filter installed		

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Jefferson High School	Gym - South (outside building)		6/22/12	elkay in-wall	4	2					
Jefferson High School	Gym B floor east		6/10/12	Haws in-wall fountain	4	1					
Jefferson High School	Gym B floor west		6/10/12	Haws in-wall fountain	20	22		x	filter installed		
Jefferson High School	Gym entrance - North (outside building)		6/22/12	Kohler single bubbler	9	4					
Jefferson High School	Gym North (the outside building)		6/22/12	elkay in-wall	18	11		x	filter installed		
Jefferson High School	Near B23		6/10/12	Halsey Taylor double bubbler	64	40		x	filter installed		
Jefferson High School	Near D21		6/10/12	Haws double bubbler	48	21		x	filter installed		
Jefferson High School	Near D33		6/10/12	central double in wall	14	65		x	filter installed		
Jefferson High School	Near dance offices		6/10/12	Haws single bubbler	22	2		x	filter installed		
Jefferson High School	Near locker c376		6/10/12	Halsey Taylor double bubbler	65	14		x	filter installed		
Jefferson High School	Near TV studio		6/10/12	Haws single bubbler	150	140		x	filter installed		
Jefferson High School	North dance studio		6/10/12	haws in wall	10	10					
Jefferson High School	South dance studio		6/10/12		11	8					
Jefferson High School	West Cafeteria		6/10/12	Elkay single bubbler	8	9					
Kelly Elementary School	Across from gym		1/16/12	Elkay single bubbler	0	0					
Kelly Elementary School	Across from Rm 116		1/16/12	Crane single bubbler	4	1					
Kelly Elementary School	Left in hallway of Kelly Center		1/16/12	Elkay double bubbler	7						
Kelly Elementary School	Music rm, portable		1/16/12	Central single bubbler	174	32		x	filter installed		
Kelly Elementary School	Near Rm 108		1/16/12	Crane single bubbler	0	0					
Kelly Elementary School	Right in hallway of Kelly Center		1/16/12	Elkay double bubbler	7	0					
Kelly Elementary School	Rm 10		1/16/12	Chicago sink drinker	5	6					
Kelly Elementary School	Rm 101		1/16/12	Central single bubbler	11	0					
Kelly Elementary School	Rm 2		2/15/12	sink	3	0					
Kelly Elementary School	Rm 23		1/16/12	sink	15						
			1/16/12								
Kelly Elementary School	Rm 25			sink (chicago brand)	32			x	kelly center - fixture removed, replumbed with plastic (field verified)		
Kelly Elementary School	Rm 29		1/16/12	Chicago sink drinker	0	0					
Kelly Elementary School	Rm 29		1/16/12	sink	10						
			2/15/12								
Kelly Elementary School	Rm 7			Sink	34	0		x	Kelly Center - appears faucet has been replaced as has the plumbing (field verified)		
			1/16/12								
Kelly Elementary School	Rm 7 (Lounge)			Sink	140			x	Kelly Center - appears faucet has been replaced as has the plumbing (field verified)		
King Elementary School	Gym East		3/25/12	Central double bubbler	8	3					
King Elementary School	Gym West		3/25/12	Central double bubbler	59	18		x	filter installed		
King Elementary School	King neighborhood lobby - left		7/15/12	Elkay double bubbler	6						
King Elementary School	King Neighborhood lobby right		7/15/12	Elkay double bubbler	4	5					
King Elementary School	Rm 141		3/25/12	Central single bubbler	10	4					
King Elementary School	Rm 142		3/25/12	Central sink drinker	6	2					
King Elementary School	Rm 211		3/25/12	Central single bubbler	9	10					
Lane Middle School	Rm 130		1/23/12	Chicago sink drinker	6						
Lane Middle School	Rm 147		1/23/12	Chicago sink drinker	6						
Lane Middle School	Room 102		3/5/12	Sink for drinking	8	2					
Lane Middle School	Room 103		3/5/12	Sink for drinking	10	2					
Laurelhurst Elementary School	Near main office		3/4/12	Elkay single bubbler	0	0					
Laurelhurst Elementary School	Near room 17		3/4/12			0					
Laurelhurst Elementary School	Near room 211 - filter		3/4/12		0						
Lee Elementary School	Gym		4/15/12	sunroc in-wall fountain	0	0					
Lee Elementary School	Near boiler room		4/15/12	Elkay single bubbler	0	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Lee Elementary School	Near boys locker room		4/15/12	Kohler in-wall fountain	5	1					
Lee Elementary School	Room 100		4/15/12	Chicago sink drinker	10	5					
Lee Elementary School	Room 101		4/15/12	Chicago sink drinker	7	3					
Lee Elementary School	Room 110 Left		4/18/12	Chicago sink drinker	14	5					
Lee Elementary School	Room 110 Right		4/15/12	Chicago sink drinker	13	3					
Lee Elementary School	Room 114		4/15/12	Chicago sink drinker	9	2					
Lee Elementary School	Room 123		4/15/12	Haws sink drinker	10	3					
Lent Elementary School	136A		2/27/12	Chicago sink drinker	2	1					
Lent Elementary School	Between 201 and 202		7/7/12	Haws single bubbler	4	2					
Lent Elementary School	Near Rm 137		2/4/12	Elkay single bubbler	0	0					
Lent Elementary School	Near Rm 151		2/27/12	Elkay single bubbler	7	6					
Lent Elementary School	Near Rm 33		2/27/12	Elkay single bubbler	3	0					
Lent Elementary School	Rm 110		2/4/12	Chicago sink drinker	0	0					
Lent Elementary School	Rm 149		2/27/12	Central single bubbler	4	5					
Lewis Elementary School	Cafeteria Fountain	1	1/21/16		0	0					
Lewis Elementary School	Fountain by Room 6	hallway	1/21/16	Single bubbler	0						
Lewis Elementary School	Gym in wall Fountain	Gym	1/21/16	Single bubbler	0						
Lewis Elementary School	Hall Fountian by room 29		1/21/16	Single bubbler	0						
Lewis Elementary School	Hallway by Room 37	37	1/27/16	Central single bubbler	0						
Lewis Elementary School	Hallway Fountain near room 13		1/21/16	Central single bubbler	0						
Lewis Elementary School	Kitchen Food Prep Sink	Kitchen	1/21/16	COLD WATER FAUCET	0						
Lewis Elementary School	Library room 19 fountain	19	1/21/16		0						
Lewis Elementary School	Room 1 H/T Fountain	1	1/21/16	Halsey Taylor single bubbler	0						
Lewis Elementary School	Room 10 Fountain	10	1/21/16	Central single bubbler	0						
Lewis Elementary School	Room 12 fountain	12	1/21/16	Central single bubbler	0						
Lewis Elementary School	Room 13 fountain	13	1/21/16	Haws sink drinker	3						
Lewis Elementary School	Room 14 Fountain	14	1/21/16	Central single bubbler	2						
Lewis Elementary School	Room 15	15	1/27/16	Central single bubbler	0						
Lewis Elementary School	Room 16	16	1/27/16	Central single bubbler	0						
Lewis Elementary School	Room 17	17	1/21/16	Central single bubbler	0						
Lewis Elementary School	Room 18 Fountain	18	1/21/16	Single bubbler	0						
Lewis Elementary School	Room 2 Fountain	2	1/21/16	Halsey Taylor single bubbler	0						
Lewis Elementary School	Room 20 Fountain	20	1/21/16	Single bubbler	4						
Lewis Elementary School	Room 21 Fountain	21	1/21/16	Single bubbler	0						
Lewis Elementary School	Room 21 Fountain	21	1/21/16	Single bubbler	0						
Lewis Elementary School	Room 22 Fountain	22	1/21/16	Single bubbler	0						
Lewis Elementary School	Room 22 Fountain	22	1/21/16	Single bubbler	0						
Lewis Elementary School	Room 3 Fountain	3	1/21/16	Halsey Taylor single bubbler	0						
Lewis Elementary School	Room 4 Fountain	4	1/21/16	Central single bubbler	0						
Lewis Elementary School	Room 5 Fountain	5	1/21/16	Central single bubbler	2						
Lewis Elementary School	Room 5 Fountain	5	1/21/16	Central single bubbler	0						
Lewis Elementary School	Room 6 Fountain	6	1/21/16	Haws single bubbler	0						
Lewis Elementary School	Room 7 Fountain	7	1/21/16	Central single bubbler	0						
Lewis Elementary School	Room 8 fountain	8	1/21/16	Halsey Taylor single bubbler	0						
Lincoln High School	Near gym - middle fountain		7/15/12	Elkay single bubbler	3	0					
Lincoln High School	Wrestling room		7/15/12	Single bubbler	6						
Llewellyn Elementary School	102		1/16/12	Chicago sink drinker	5	3					
Llewellyn Elementary School	Near 205		1/16/12	Double fountain	1						
Llewellyn Elementary School	North portable		1/16/12	Chicago sink drinker	5	5					
Llewellyn Elementary School	Rm 103		1/16/12	Chicago sink drinker	5	6					
Llewellyn Elementary School	Rm 202		1/16/12		4	10					
Llewellyn Elementary School	Rm 210		1/16/12	Chicago sink drinker	6	0					
Madison High School	A16		6/17/12	Chicago sink drinker	3	1					
Madison High School	A19		6/17/12	Central single bubbler	9	2					
Madison High School	Apparatus room		6/21/12	Standard in-wall fountain	3	1					
Madison High School	Boys locker room		6/21/12	Standard in-wall fountain	2	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Madison High School	East sink in nursery		4/15/12	sink	2	1					
Madison High School	Girls locker room		6/21/12	Haws in-wall fountain	2	1					
Madison High School	Gym - East		7/9/12	In-wall fountain	1	0					
Madison High School	Gym west		6/21/12	Haws in-wall fountain	3	0					
Madison High School	Left bathroom sink - nursery		4/15/12	sink	3	3					
Madison High School	left kitchen sink - nursery		4/15/12	sink	4	1					
Madison High School	Near A2 left		6/21/12	Elkay double bubbler	1						
Madison High School	Near A2 right		6/21/12	Elkay double bubbler	0	1					
Madison High School	Near B40 Left		6/17/12	Central triple bubbler	2	0					
Madison High School	Near B40 right		6/17/12	Central triple bubbler	1	0					
Madison High School	Near B42 Left		6/17/12	Central triple bubbler	2	0					
Madison High School	Near B42 Middle		6/17/12	Central triple bubbler	2						
Madison High School	Near B42 Right		6/17/12	Central triple bubbler	3						
Madison High School	Near B58 Left		6/17/12	Central double bubbler	0	0					
Madison High School	Near B58 Right		6/17/12	Central double bubbler	1	0					
Madison High School	Near B68 Left		6/17/12	Central double bubbler	0	0					
Madison High School	Near B68 right		6/17/12	Central double bubbler	0						
Madison High School	Near C42 Left		6/17/12	Central triple bubbler	4	2					
Madison High School	Near C42 middle		6/17/12	Central triple bubbler	4						
Madison High School	Near C42 Right		6/17/12	Central triple bubbler	4						
Madison High School	North cafeteria		6/17/12	Elkay single bubbler	0	0					
Madison High School	Right bathroom sink - nursery		4/15/12	sink	5	3					
Madison High School	Right kitchen sink - nursery		4/15/12	sink	3	2					
Madison High School	Weight room		6/21/12	Central single bubbler	1	0					
Madison High School	West sink in nursery		4/15/12	sink	2	1					
Maplewood Elementary School	A1		2/1/12	Chicago sink drinker	3						
Maplewood Elementary School	A2		2/1/12	Chicago sink drinker	6	2					
Maplewood Elementary School	Outside left		7/16/12	Double fountain	4						
Maplewood Elementary School	Outside, left		7/9/12	Double fountain		0					
Markham Elementary School	Auditorium		12/19/11		6	8					
Markham Elementary School	Cafeteria		12/19/11		2						
Markham Elementary School	Room 133		7/2/12	Standard single bubbler	54	56	x	filter installed			
Marshall High School	A22		6/25/12	Haws single bubbler	130	10	x	filter installed			
Marshall High School	A26		6/25/12	Haws single bubbler	24	3	x	filter installed			
Marshall High School	A4		6/25/12	Haws single bubbler	250	95	x	filter installed			
Marshall High School	A9		7/7/12	Haws single bubbler	49	17	x	filter installed			
Marshall High School	Basement Locker Room		4/19/05		7	4					
Marshall High School	Boys locker room		6/27/12	Haws in-wall fountain	28	17	x	filter installed			
Marshall High School	Cafeteria		4/19/05	Haws single bubbler	4	4					
Marshall High School	East cafeteria		6/25/12	Haws in-wall fountain	17	5	x	filter installed			
Marshall High School	Girls locker room		6/27/12	Haws single bubbler	23	23	x	filter installed			
Marshall High School	Gym - north		6/27/12	In-wall fountain	5	3					
Marshall High School	Gym - South		6/27/12	In-wall fountain	8	2					
Marshall High School	Gym Entry Lower		4/19/05	Elkay single bubbler	11	3					
Marshall High School	Gym Entry Upper		4/19/05	Elkay single bubbler	4	4					
Marshall High School	Gym lobby		6/27/12		0						
Marshall High School	Hall A Sun Center Left		4/19/05	Elkay double bubbler	0	4					
Marshall High School	Hall A Sun Center Right		4/19/05	Elkay double bubbler	3	5					
Marshall High School	Hall by B 17 - Left		4/19/05	Central double bubbler	4	0					
Marshall High School	Hall by B 17 - Right		4/19/05	Central double bubbler	3	0					
Marshall High School	Hall by B 35 - Left		4/19/05	Central double bubbler	0	2					
Marshall High School	Hall by B 35 - Right		4/19/05	Central double bubbler	0	3					
Marshall High School	Hall by B 56 - Left		4/19/05	Central double bubbler	1	7					
Marshall High School	Hall by B 56 - Right		4/19/05	Central double bubbler	6	5					
Marshall High School	Hall by B 6 - right		4/19/05	Chicago double bubbler	4	3					
Marshall High School	Hall by B6 - Left		4/19/05	Chicago double bubbler	3	4					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Marshall High School	Hall by C 26 - Left		4/19/05	Elkay double bubbler	0	0					
Marshall High School	Hall by C 26 Right		4/19/05	Central double bubbler	0	0					
Marshall High School	Hall by C 36 - Left		4/19/05	Chicago double bubbler	3	5					
Marshall High School	Hall by C 36 - Right		4/19/05	Chicago double bubbler	4	6					
Marshall High School	Hall by C 36 Left		4/19/05	Central double bubbler	4	0					
Marshall High School	Hall by C 36 Right		4/19/05	Central double bubbler	4	3					
Marshall High School	Near B56		6/25/12	Chicago double bubbler		30		x	filter installed		
Marshall High School	Near B61		6/25/12	Haws single bubbler	30	27		x	filter installed		
Marshall High School	West cafeteria		6/25/12	Haws in-wall fountain	8	0					
Marshall High School	Wrestling room		6/27/12	In-wall fountain	48	35		x	filter installed		
Metropolitan Learning Center	Near rm 204		1/23/12	Central single bubbler	0						
Metropolitan Learning Center	Near rm 301		1/23/12	Central single bubbler	1	0					
Mt. Tabor Middle School	Across from cafeteria		3/5/12	Elkay single bubbler	0	0					
Mt. Tabor Middle School	Cafeteria		3/5/12	Central single bubbler	1						
Mt. Tabor Middle School	Girls locker room		3/5/12	Standard single bubbler	1	0					
Mt. Tabor Middle School	Room 113		3/5/12	Central single bubbler	0	0					
Mt. Tabor Middle School	Room 130		3/5/12	Chicago sink drinker	0	0					
Mt. Tabor Middle School	Room 133		3/5/12	Haws single bubbler	4	0					
Mt. Tabor Middle School	Room 210		3/5/12	Chicago sink drinker	1						
Ockley Green Middle School	Near Rm 113		4/1/12	sunroc single bubbler	0	0					
Ockley Green Middle School	Near Rm 217		4/1/12		5	0					
Ockley Green Middle School	Rm 102		4/1/12	elkay sink drinker	3	0					
Ockley Green Middle School	Rm 104		4/1/12	elkay sink drinker	5	0					
Ockley Green Middle School			1/20/16	COLD WATER FAUCET	7	4					
Peninsula Elementary School	Cafetorium		12/22/11	Haws single bubbler	1						
Peninsula Elementary School	Kitchen food prep		6/25/12	food prep sink	5						
Peninsula Elementary School	Kitchen Food prep sink other		12/22/11		20			x		x	no filter - field verified
Peninsula Elementary School	Near room 113		12/22/11	fountain	0	0					
Peninsula Elementary School	Near room 126		12/22/11	fountain	3	0					
Peninsula Elementary School	Room 100		12/22/11	Haws single bubbler	2	0					
Peninsula Elementary School	Room 106		12/22/11	Elkay single bubbler	0	0					
Peninsula Elementary School	Room 126		12/22/11	Elkay single bubbler	1	0					
Ramona Headstart	134		7/8/12	Sink	5						
Ramona Headstart	134		7/8/12	Chicago sink drinker	6	18		x	filter installed		
Ramona Headstart	135		7/8/12	Chicago sink drinker	10	38		x	filter installed		
Ramona Headstart	135		7/8/12	sink	10						
Ramona Headstart	Rm 157		7/8/12	Chicago sink drinker	11	39		x	filter installed		
Ramona Headstart	Rm 158		7/8/12	Chicago sink drinker	13	2					
Ramona Headstart	Rm 159		7/8/12		7	3					
Ramona Headstart	Rm 160		7/8/12	Chicago sink drinker	8	2					
Ramona Headstart	South big area left		7/8/12	Single bubbler	10	3					
Ramona Headstart	South big area right		7/8/12	Single bubbler	13	4					
Rice Site	Rm 3		7/5/12	Haws sink drinker	25	36		x	filter installed		
Rice Site	Rm 6		7/5/12	Haws sink drinker	25	47		x	filter installed		
Rice Site	Storereroom 1		7/5/12	Haws sink drinker	1700	250		x	filter installed		
Richmond Elementary School	Near Rm 102		2/19/12	Central single bubbler	0						
Richmond Elementary School	Near Rm 202		2/19/12	Elkay double bubbler	0	0					
Richmond Elementary School	Near Rm 23		2/19/12	Central quad bubbler	0	0					
Richmond Elementary School	Rm 102		2/19/12	Chicago sink drinker	2	0					
Richmond Elementary School	Rm 103		2/19/12	elkay sink drinker	1	0					
Richmond Elementary School	Rm 106		2/19/12	Central sink drinker	1	0					
Richmond Elementary School	Rm 20		2/19/12	Halsey Taylor single bubbler		0					
Rieke Elementary School	Library		12/21/11	Chicago sink drinker	0						
Rieke Elementary School	Near room 12		12/21/11	Halsey Taylor single bubbler	0						
Rieke Elementary School	Outside gym		12/21/11	Central single bubbler	16	18		x	filter installed		
Roosevelt High School	Boys locker room near 99A		6/20/12		50	25		x	filter installed		

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Roosevelt High School	Boys locker room near G22		6/20/12		2	0					
Roosevelt High School	Crib room		3/31/12	sink faucet	24	3		x	filter installed		
Roosevelt High School	Far play room		3/31/12	sink	9	0					
Roosevelt High School	Near room 115		5/28/12	Central single bubbler	3	0					
Roosevelt High School	Near Room 175 - filter		5/28/12	Elkay single bubbler	2						
Roosevelt High School	Near Room 236 Left		5/28/12	elkay in wall	3						
Roosevelt High School	Near Room 236 Right		5/28/12	elkay in wall	1	0					
Roosevelt High School	Near Room G239 Right		5/28/12	elkay in-wall fountain	6	0					
Roosevelt High School	Near Room L249		5/28/12	Elkay single bubbler	10	4					
Roosevelt High School	Near Room M145 - filter		5/28/12	Elkay single bubbler	2						
Roosevelt High School	Nursery wash sink		3/31/12	sink faucet	4	0					
Roosevelt High School	Play room		3/31/12	sink	7	0					
Roosevelt High School	Rm 128		3/31/12	Halsey Taylor single bubbler	19	16		x	filter installed		
Roosevelt High School	Rm 129		3/31/12	Central single bubbler	28	69		x	fixture replaced, filter installed		
Roosevelt High School	Room A180		5/28/12	Central double bubbler	17	26		x	filter installed		
Roosevelt High School	Room M149		5/28/12	Haws single bubbler	25	19		x	filter installed		
Roosevelt High School	Room M152		5/28/12	Haws single bubbler	23	17		x	filter installed		
Rosa Parks Elementary School	101		7/4/12	Chicago sink drinker	8	2					
Rosa Parks Elementary School	102		7/4/12	Chicago sink drinker	6	5					
Rosa Parks Elementary School	106		7/4/12	Chicago sink drinker	7	4					
Rosa Parks Elementary School	107		7/4/12	Chicago sink drinker	2	2					
Rosa Parks Elementary School	108		7/4/12	Chicago sink drinker	3	2					
Rosa Parks Elementary School	109		7/4/12	Chicago sink drinker	7	6					
Rosa Parks Elementary School	110		7/4/12	Chicago sink drinker	13	9					
Rosa Parks Elementary School	111		7/4/12	Chicago sink drinker	12	10					
Rosa Parks Elementary School	206		7/4/12	Chicago sink drinker	4	1					
Rosa Parks Elementary School	Near 114 left		7/4/12	Haws double bubbler	6						
Rosa Parks Elementary School	Near 114 right		7/4/12	Haws double bubbler	6	2					
Rosa Parks Elementary School	Near 115 left		7/4/12	Haws double bubbler	34	2		x	filter installed		
Rosa Parks Elementary School	Near 115 right		7/4/12	Haws double bubbler	4						
Rosa Parks Elementary School	Near 214 left		7/8/12	Haws double bubbler	3						
Rosa Parks Elementary School	Near 214 right		7/8/12	Haws double bubbler	6	3					
Rosa Parks Elementary School	Near 215 right		7/8/12	Haws double bubbler	5						
Rosa Parks Elementary School	Near left		7/8/12	Haws double bubbler	7	2					
Rosa Parks Elementary School	Rm 103		7/8/12	Chicago sink drinker	3	1					
Rosa Parks Elementary School	Rm 104		7/8/12	Chicago sink drinker	13	3					
Rosa Parks Elementary School	Rm 201		7/8/12	Chicago sink drinker	5	3					
Rosa Parks Elementary School	Rm 202		7/8/12	Chicago sink drinker	12	4					
Rosa Parks Elementary School	Rm 203		7/8/12	Chicago sink drinker	3	2					
Rosa Parks Elementary School	Rm 204		7/8/12	Chicago sink drinker	9	4					
Rosa Parks Elementary School	Rm 205		7/8/12	Chicago sink drinker	9	3					
Rosa Parks Elementary School	Rm 207		7/8/12	Chicago sink drinker	6	2					
Rosa Parks Elementary School	Rm 208		7/8/12	Chicago sink drinker	5	3					
Rosa Parks Elementary School	Rm 209		7/8/12	Chicago sink drinker	8	6					
Rosa Parks Elementary School	Rm 210		7/8/12	Chicago sink drinker	12	11					
Rosa Parks Elementary School	Rm 211		7/8/12		14	8					
Rose City Park Elementary School	Gym	Gym	3/22/16	Central single bubbler	0						
Rose City Park Elementary School	Hall Fountain by 204	hall by 204	3/22/16	Central single bubbler	5						
Rose City Park Elementary School	Hall Fountain by 208	hall by 208	3/22/16	Central single bubbler	0						
Rose City Park Elementary School	Hall Fountain by room 3	hall by room 3	3/22/16	Central single bubbler	4						
Rose City Park Elementary School	Hallway fountain by 109	hallway by 109	3/22/16	Central double bubbler	4						
Rose City Park Elementary School	Kitchen Food Prep Sink	Kitchen	3/22/16	Sink fixture	3	0					
Rose City Park Elementary School	Library	Library	3/22/16	Sink fixture	14	7					
Rose City Park Elementary School	North hall Gym Fountain	North Hall	3/22/16	Central single bubbler	2						
Rose City Park Elementary School	Rm 115		3/19/12	Chicago sink drinker	5	2					
Rose City Park Elementary School	Rm 116		3/19/12	Chicago sink drinker	3	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Rose City Park Elementary School	Rm 16		3/19/12	elkay sink drinker	3	0					
Rose City Park Elementary School	Room 1- Corner Sink	101	3/22/16	Sink fixture	27	18	x	x	sign posted		
Rose City Park Elementary School	Room 1- sink by entry door	1	3/22/16	Sink fixture	29	10	x	x	sign posted		
Rose City Park Elementary School	Room 1- sink by exterior door	1	3/22/16	Sink fixture	30	30	x	x	sign posted		
Rose City Park Elementary School	Room 100	100	3/22/16	Sink fixture	13	4					
Rose City Park Elementary School	Room 100	100	3/22/16	Chicago single bubbler	4						
Rose City Park Elementary School	Room 103	103	3/22/16	Sink fixture	4	4					
Rose City Park Elementary School	Room 112	112	3/22/16	Chicago single bubbler	3						
Rose City Park Elementary School	Room 112	112	3/22/16	Sink fixture	5	9					
Rose City Park Elementary School	room 115	115	3/22/16	Sink fixture	6	2					
Rose City Park Elementary School	Room 116	116	3/22/16	Sink fixture	5	3					
Rose City Park Elementary School	Room 116	116	3/22/16	Chicago single bubbler	7						
Rose City Park Elementary School	Room 16	16	3/22/16	Central single bubbler	5						
Rose City Park Elementary School	Room 16	16	3/22/16	Sink fixture	6	0					
Rose City Park Elementary School	Room 17	17	3/22/16	Sink fixture	13	0					
Rose City Park Elementary School	Room 2	2	3/22/16	Sink fixture	26	21	x	x	sign posted		
Rose City Park Elementary School	Room 200	200	3/22/16	Chicago single bubbler	31		x	x	fixture replaced		
Rose City Park Elementary School	Room 200	200	3/22/16	Sink fixture	14	6					
Rose City Park Elementary School	Room 200- fountain	200	5/6/16	Single bubbler	5						
Rose City Park Elementary School	Room 203	203	3/22/16	Sink fixture	13	4					
Rose City Park Elementary School	Room 203	203	3/22/16	Central single bubbler	7						
Rose City Park Elementary School	Room 207	207	3/22/16	Sink fixture	34	14	x	x	fixture replaced		
Rose City Park Elementary School	Room 207- Sink	207	5/6/16	COLD WATER FAUCET	7	0					
Rose City Park Elementary School	Room 211	211	3/22/16	Sink fixture	4	3					
Rose City Park Elementary School	Room 211	211	3/22/16	Chicago single bubbler	4						
Rose City Park Elementary School	Room 215	215	3/22/16	Lever Bubbler	0						
Rose City Park Elementary School	Room 3	3	3/22/16	Chicago single bubbler	22		x	x	fixture replaced		
Rose City Park Elementary School	Room 3	3	3/22/16	Sink fixture	7	3					
Rose City Park Elementary School	Room 3- fountain	3	5/6/16	Single bubbler	5						
Rose City Park Elementary School	Room 9	9	3/22/16	Sink fixture	22	6	x	x	fixture replaced		
Rose City Park Elementary School	Room 9- Sink	9	5/6/16	COLD WATER FAUCET	5	0					
Rose City Park Elementary School	South Cafeteria Hallway	South Cafeteria Hallway	3/22/16	Central single bubbler	4						
Roseway Heights Middle School	Near Room 124		4/15/12	Central double bubbler	1	0					
Roseway Heights Middle School	Near room 222		4/15/12	Central single bubbler	2	0					
Roseway Heights Middle School	Near Room 247		4/15/12	Elkay single bubbler	0	0					
Roseway Heights Middle School	Rm 129		7/15/12	Double fountain	1						
Roseway Heights Middle School	Rm 184		7/7/12	Central sink drinker	9	2					
Roseway Heights Middle School	Room 122		4/15/12	sink	2	1					
Roseway Heights Middle School	Room 125		4/15/12	sink	1	0					
Roseway Heights Middle School	Room 184 - very low flow		4/15/12	Central sink drinker	4	1					
Roseway Heights Middle School	Room 214		4/15/12	Central single bubbler	14	2					
Roseway Heights Middle School	Room 225		4/15/12	Elkay single bubbler	2						
Sabin Elementary School	220C		3/25/12	Central single bubbler	76	29		x	filter installed		
Sabin Elementary School	Near Rm 113		3/25/12	Elkay single bubbler	0						
Sabin Elementary School	Near Rm 304		3/25/12	Central double bubbler	6						
Sabin Elementary School	P5		3/25/12	Chicago sink drinker	4	1					
Sabin Elementary School	Rm 314		3/25/12	Chicago sink drinker	10	2					
Sabin Elementary School	Room 111 - filter		7/2/12	Chicago sink drinker	2						
Sacajawea Head Start	Near Room 101		4/9/12	Elkay single bubbler	6	19		x	fixture replaced, filter installed (11/5/01)		
Sacajawea Head Start	Near Room 106		4/9/12	Central single bubbler	6	7					
Sacajawea Head Start	Room 100		4/9/12	sink	10						
Scott Elementary School	Near Rm 207		3/25/12	sunroc single bubbler	0	0					
Scott Elementary School	Rm 101		3/25/12	Central single bubbler	17	10		x	filter installed		
Scott Elementary School	Rm 201		3/25/12	Elkay single bubbler	19	14		x	filter installed		
Scott Elementary School	Rm 202		3/25/12	Central single bubbler	89	34		x	filter installed		
Scott Elementary School	Rm 204		3/25/12	Central single bubbler	8	17		x	filter installed		

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Scott Elementary School	Rm 301		3/25/12	Central single bubbler	19	4		x	filter installed		
Scott Elementary School	Rm 305		3/25/12	Central single bubbler	8	2					
Sellwood Middle School	Near 105		1/16/12	Double fountain	2	11					
Sellwood Middle School	Near 220		1/16/12	Double fountain	1	0					
Sellwood Middle School	Near 307 left		1/16/12	Double fountain	20			x	filter installed		
Sellwood Middle School	Near 320		1/16/12	Double fountain	10	18		x	filter installed		
Sellwood Middle School	Rm 129		1/16/12	Haws sink drinker	2						
Sellwood Middle School	Rm 135		1/16/12	Sink drinker	8	5					
Sellwood Middle School	Rm 145		1/16/12	Haws sink drinker	1	0					
Sitton Elementary School	Near Library		4/8/12	Central single bubbler	16	1		x	filter installed		
Sitton Elementary School	Near Room 11 - filter		4/8/12	Halsey Taylor single bubbler	0						
Sitton Elementary School	Near Room 5		4/8/12	Central single bubbler	12	10					
Sitton Elementary School	Near Room 7		4/8/12	Central single bubbler	5	2					
Sitton Elementary School	Office		4/8/12	Chicago single bubbler	7	3					
Sitton Elementary School	Rm 15		7/1/12	Chicago sink drinker	33			x	filter installed		
Sitton Elementary School	Rm 16		7/1/12	Chicago sink drinker	21			x	filter installed		
Sitton Elementary School	Room 1		4/8/12	Standard single bubbler	6	8					
Sitton Elementary School	Room 11		4/8/12	Chicago sink drinker	7						
Sitton Elementary School	Room 14		4/8/12	Chicago sink drinker	37			x	filter installed		
Sitton Elementary School	Room 18		4/8/12	Chicago sink drinker	13						
Sitton Elementary School	Room 2 - low flow		4/8/12	Elkay single bubbler	1	0					
Sitton Elementary School	Room 4		4/8/12	Central single bubbler	39	7		x	filter installed		
Sitton Elementary School	Room 8		4/8/12	Standard single bubbler	8	23		x	filter installed		
Sitton Elementary School	Room 9		4/8/12	Standard single bubbler	4	5					
Skyline Elementary School	Classroom 110 Fountain	110	9/11/15		0						
Skyline Elementary School	Fountain by Main Office		9/11/15	Central single bubbler	0						
Skyline Elementary School	Hall by Cafeteria		9/11/15	Central single bubbler	0						
Skyline Elementary School	Hall Fountain by room 201		9/11/15	Central single bubbler	0						
Skyline Elementary School	Kitchen		9/11/15	COLD WATER FAUCET	0						
Skyline Elementary School	Near 201		1/23/12	western single bubbler	3						
Skyline Elementary School	Near Rm 204		1/23/12	Elkay single bubbler	0						
Skyline Elementary School	Rm 110		1/23/12	Chicago sink drinker	2	0					
Stephenson Elementary School	Rm 137		2/5/12		7	0					
Sunnyside Elementary School	Near Office		2/18/12	Elkay single bubbler	4	1					
Sunnyside Elementary School	Outside north ftn - leaky at base of ftn		7/16/12	Haws double bubbler	0	0					
Sunnyside Elementary School	Outside south ftn - leaky at base		7/16/12	Haws double bubbler	0						
Tubman Middle School	Near Rm 132C		3/17/12	Central sink drinker	38	14		x	filter installed		
Tubman Middle School	Near Rm 154 Left		3/17/12	Central single bubbler	2	0					
Tubman Middle School	Near Rm 154 Right		3/17/12	Central single bubbler	1	0					
Tubman Middle School	Near Rm 159 - Filter present		3/17/12	Central single bubbler	0						
Tubman Middle School	Near Rm 215 - filter present		3/17/12	Elkay single bubbler	0						
Tubman Middle School	Rm 113		3/17/12	Chicago sink drinker	8	2					
Tubman Middle School	Rm 120		3/17/12	Central sink drinker	12	4					
Tubman Middle School	Rm 200 low flow		3/17/12	Central single bubbler	29	31		x	filter installed		
Tubman Middle School	Rm 202		3/17/12	Halsey Taylor single bubbler	5	11					
Tubman Middle School	Rm 206 low flow		3/17/12	Halsey Taylor single bubbler	20	17		x	filter installed		
Vernon Elementary School	Near Rm 108		3/25/12	Elkay single bubbler	0	0					
Vernon Elementary School	Rm 102		3/25/12	Crane single bubbler	1	1					
Vernon Elementary School	Rm 304		3/25/12	Elkay single bubbler	5	4					
Vernon Elementary School	Room 202		4/15/12	Crane single bubbler	130	0		x		x	no filter, same fixture - field verified
Vernon Elementary School	Room 303		5/6/12	Standard single bubbler	5	3					
Vestal Elementary School	Near room 207		3/4/12	Central double bubbler	5	4					
Vestal Elementary School	Room 101		3/4/12	Central single bubbler	3	3					
West Sylvan Middle School	Kitchen left faucet - food prep		1/22/12	sink	15						
West Sylvan Middle School	Kitchen right faucet - food prep		1/22/12	sink	12						
West Sylvan Middle School	Near 101		7/18/12	Haws single bubbler	10						

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
West Sylvan Middle School	Near rm 158		1/22/12	Elkay single bubbler	6						
West Sylvan Middle School	Upper gym		1/22/12	Central single bubbler	13						
Whitman Elementary School	Across from Rm 7 - filter		2/15/12	Central single bubbler	9						
Whitman Elementary School	Across from Rm 9		2/5/12	Haws sink drinker	3	0					
Whitman Elementary School	Cafeteria		2/5/12	in-wall fountain	3	4					
Whitman Elementary School	Gym		2/5/12	Haws in-wall fountain	7	0					
Whitman Elementary School	Kitchen- Food Prep Sink	Kitchen	1/13/15	COLD WATER FAUCET	0						
Whitman Elementary School	Near C1		2/5/12	Central single bubbler	14	18		x	filter installed		
Whitman Elementary School	Near Rm 12		2/11/12	haws single bubbler?	27	1		x	filter installed		
Whitman Elementary School	Near Rm 17		2/11/12	Haws single bubbler	18	4		x	filter installed		
Whitman Elementary School	Near Rm 22		2/11/12	Central single bubbler	8	1					
Whitman Elementary School	Near Rm 3		2/5/12	Elkay single bubbler	2	1					
Whitman Elementary School	Rm 1		2/5/12	Haws sink drinker	17	14		x	filter installed		
Whitman Elementary School	Rm 12		7/8/12	Haws sink drinker	27			x		x	no filter - field verified
Whitman Elementary School	Rm 20		7/8/12	Haws sink drinker	37	33		x	filter installed		
Whitman Elementary School	Rm 23		7/8/12	Haws sink drinker	36			x	filter installed		
Whitman Elementary School	Rm 6		2/5/12	Haws sink drinker	8	8					
Whitman Elementary School	Rm 8		2/5/12	Haws single bubbler	7	2					
Wilcox Elementary School	Portable		6/11/12	Elkay single bubbler	4	0					
Wilson High School	By pool south		7/18/12	Single bubbler	9	10					
Wilson High School	By Rm 132 Left		12/1/11		10	14					
Wilson High School	By Rm 209 Middle		12/1/11		4	5					
Wilson High School	By Rm 245 Middle		12/1/11		19	30	x	x			
Wilson High School	By Rm 30A Left		12/1/11		3	6					
Wilson High School	Gym by boy's locker rm		12/1/11		2	0					
Wilson High School	Gym northeast		1/30/12	haws in wall	6	1					
Wilson High School	Gym northwest		7/2/12	Haws in-wall fountain	13	2					
Wilson High School	Gym southeast		1/30/12		9	5					
Wilson High School	Near 11		7/18/12	Central in-wall fountain		12					
Wilson High School	Near 209		7/2/12			6					
Wilson High School	Near 212		7/18/12	Central triple bubbler	5						
Wilson High School	Near Rm 11		12/1/11		15	3					
Wilson High School	Near Rm 245		7/18/12	Central quad bubbler	9	2	x				
Wilson High School	Near Rm 34		12/1/11		5	1					
Winterhaven School	Near rm 6 - right		1/22/12	Central double bubbler	9	2					
Winterhaven School	Outside		7/2/12	Central single bubbler	2	0					
Woodlawn Elementary School	Annex 3		4/1/12	elkay sink drinker	3	6					
Woodlawn Elementary School	Near Rm 152		4/1/12	sunroc single bubbler	0	0					
Woodlawn Elementary School	Near Rm 211		4/1/12	Central single bubbler	3	0					
Woodlawn Elementary School	Rm 122		4/1/12	Haws sink drinker	0						
Woodmere Elementary School	Gym		9/9/04	Haws single bubbler	4	0					
Woodmere Elementary School	Hall by Room 14		9/9/04	Central single bubbler	4	0					
Woodmere Elementary School	Near rm 31		1/7/12	Elkay single bubbler	0	0					
Woodmere Elementary School	Rm 23		1/7/12		1	0					
Woodmere Elementary School	Rm 24		1/7/12		35			x	filter installed		
Woodmere Elementary School	Rm 27		1/7/12		3						
Woodmere Elementary School	Room 13	13	9/9/04	Chicago single bubbler	2	0					
Woodmere Elementary School	Room 15		9/9/04	Chicago sink drinker	2	0					
Woodmere Elementary School	Room 16		9/9/04	Chicago sink drinker	3	0					
Woodmere Elementary School	Room 21		9/9/04	Haws sink drinker	2	0					
Woodmere Elementary School	Room 22		9/9/04	Haws sink drinker	2	0					
Woodmere Elementary School	Room 23		9/9/04	Central single bubbler	11	0					
Woodmere Elementary School	Room 25		9/9/04	Chicago single bubbler	5	0					
Woodmere Elementary School	Room 26		9/9/04	Chicago sink drinker	3	0					
Woodmere Elementary School	Room 38		9/9/04	Haws sink drinker	7	0					
Woodmere Elementary School	Room 39		9/9/04	Haws sink drinker	6	0					

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Woodmere Elementary School	Room 40		9/9/04	Central sink drinker	7	0					
Woodmere Elementary School	Room 48		9/9/04	Haws sink drinker	2	0					
Woodmere Elementary School	Room 8		9/9/04	Chicago single bubbler	2	0					
Woodmere Elementary School	Room 9		9/9/04	Chicago single bubbler	1	0					
Woodstock Elementary School	Near faculty		2/5/12	Central double bubbler		0					
Woodstock Elementary School	Near faculty rm		2/5/12	Elkay single bubbler	3	0					
Woodstock Elementary School	Near faculty room - left fixture - filter		7/7/12	Central double bubbler	2						
Woodstock Elementary School	Near faculty room - right - filter		6/25/12	Central double bubbler	3						
Woodstock Elementary School	Near playcourt		2/5/12	Central double bubbler	46	34		x	filter installed		
Youngson Elementary School	Cafeteria		2/20/12	Central single bubbler	0	0					
Youngson Elementary School	Rm 2		2/20/12	Elkay single bubbler		3					