

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Abernethy Elementary School	Rm 16		2/11/12	Chicago sink drinker	44		x	x	filter installed		
Abernethy Elementary School	Rm 17		2/11/12	Chicago sink drinker	21		x	x	filter installed		
Abernethy Elementary School	Rm 3		7/18/12	Chicago sink drinker		19	x	x	filter installed		
Abernethy Elementary School	Teachers Lounge		2/11/12	sink	17		x	x	filter installed		
Ainsworth Elementary School	Teachers Rm		1/5/12	Haws sink drinker	32	14		x	filter installed		
Alameda Elementary School	Near Rm 201		7/18/12	Halsey Taylor single bubbler	46			x	filter installed		
Alliance High School at Meek	Near Room 106 Left		5/11/12	Elkay single bubbler	42	3		x	filter installed		
Applegate Elementary School	Room 12		5/20/12	Chicago sink drinker	18			x		x	no filter - field verified
Arleta Elementary School	Across from Rm 7		2/7/12		24	5		x	fixture replaced, filter installed 10/1/2001		
Arleta Elementary School	Cafeteria		2/7/12		16	11		x	fixture replaced, filter installed outside café (10/1/2001) same location?		
Arleta Elementary School	Room 32		2/5/12	Central single bubbler	3	16		x	filter installed		
Astor Elementary School	Rm 23		4/8/12	sexauer single bubbler	44			x	fixture replaces, filter installed 1/11/02		
Astor Elementary School	Rm 7		4/8/12	sexauere single bubbler	31			x	fixture replaces, filter installed 1/11/02		
Astor Elementary School	Room 6		9/9/04	Central single bubbler	24	0	x	x	fixture replaces, filter installed 1/11/02		
Beach Elementary School	P2		3/12/12	Haws sink drinker	21	10		x	filter installed		
Bridlemile Elementary School	Portable		6/23/12	Chicago sink drinker	46	15		x	filter installed		
Buckman Elementary School	Rm 208		2/18/12	Chicago sink drinker	23	11		x	filter installed		
Capitol Hill Elementary School	East cafeteria		1/29/12	kohler in wall	49	8		x	filter installed		
Capitol Hill Elementary School	West Cafeteria		1/29/12	kohler in wall	30	16		x	filter installed		
Chapman Elementary School	Rm 26		1/21/12	unmarked	18	7		x	filter installed		
Chief Joseph Elementary School	Near 16		7/18/12	Elkay single bubbler	12	370		x	filter installed		
Chief Joseph Elementary School	Rm 28		7/18/12	Haws sink drinker	16			x	filter installed		
Chief Joseph Elementary School	Rm 8		7/18/12	Standard single bubbler	31	67		x	filter installed		
Child Services Center	Near 13		7/14/12	Standard single bubbler	25	21		x	filter installed		

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Cleveland High School	Cafeteria right		1/22/12	Central double bubbler	17			x	filter installed		
Cleveland High School	Near 217		1/22/12	Halsey Taylor single bubbler	21			x	filter installed		
Cleveland High School	Near Rm 333		1/22/12	Central double bubbler	59	34		x	filter installed		
Cleveland High School	West boys locker room		2/20/12	Haws single bubbler	18	23		x	filter installed		
Columbia Site	Ground floor, SE corner		7/7/12	Crane in-wall fountain	570	40		x	filter installed		
Columbia Site	Gym - east		7/7/12	Central single bubbler	22	15		x	filter installed		
Columbia Site	Near Rm 9		7/7/12	Elkay single bubbler	17	6		x	filter installed		
Creative Sciences School	Rm 2		7/14/12	Sink drinker		19		x	filter installed		
Creative Sciences School	Rm 24		7/14/12	Sink drinker	17			x	filter installed		
Creative Sciences School	Rm 3		7/14/12	Central double bubbler	25	24		x	filter installed		
Creative Sciences School	Rm 4		7/14/12	Central sink drinker	23	18		x	filter installed		
Creative Sciences School	Rm 5		7/14/12	Sink drinker		51		x	filter installed		
Creative Sciences School	Rm 7		7/14/12	Central sink drinker	22	3		x	filter installed		
Creative Sciences School	Rm 8		7/14/12	Central sink drinker	22	8		x	filter installed		
Creston Annex (DRAC)		5	2/4/12	In-wall fountain	28	4		x	filter installed		
Creston Elementary School	100B cold v	100B	4/22/16	COLD WATER FAUCET	10	52		x	signage posted, outlet disabled		
Creston Elementary School	108A cold v	108A	4/22/16	COLD WATER FAUCET	26	11		x	outlet disabled		
Creston Elementary School	Annex Rm 5		2/4/12	Elkay in wall	28	4		x	filter installed		
Creston Elementary School	Kitchen Foc	Kitchen	3/22/16	Sink fixture	23	5	x	x	fixture replaced		
Creston Elementary School	Library offic	library offic	4/22/16	COLD WATER FAUCET	29	4	x	x	fixture replaced		
Creston Elementary School	Room 101	101	3/22/16	Sink fixture	18	16	x	x	fixture replaced		
Creston Elementary School	Room 111	111	3/22/16	Chicago single bubbler	33	0	x	x	fixture replaced		
Creston Elementary School	Spray Sink	Kitchen	4/22/16	COLD WATER FAUCET	24	6	x	x	fixture replaced		
DaVinci Arts Middle School	Faucet #1	107	1/9/15	COLD WATER FAUCET	18	3		x	signage posted, Teacher, students informed		
DaVinci Arts Middle School	Faucet #4	107	1/9/15	COLD WATER FAUCET	20	12		x	signage posted, Teacher, students informed		
Duniway Elementary School	Hall by Room 19		2/12/10	Central single bubbler	31	26		x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Hall by Room 19		3/18/10	Central double bubbler	21			x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Hall by Room 19		5/13/10	Central double bubbler	51	50		x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Near Rm 1		2/12/10	Central single bubbler	16	15		x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Room 1		2/12/10	central	18	12	x	x	fixture replaced, filter installed (3/15/10)		
Duniway Elementary School	Teacher's Lounge Upsta		2/12/10	Sink for drinking	34	2	x	x	fixture replaced, filter installed (3/15/10)		
Edwards Elementary School	East Office		4/22/12	elkay sink drinker	2	16		x	fixture replaces, filter installed		
Faubion Elementary School	North cafeteria		9/9/04	Standard single bubbler	22	0	x	x			

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Faubion Elementary School	Room Principal2		4/29/12	Halsey Taylor single bubbler	17	3		x		x	
Franklin High School	East of auditorium		3/11/12	Central single bubbler	22	17		x	filter installed		
Franklin High School	Rm 273		3/11/12	Thin faucet for water bottles	28	4		x		x	
George Middle School	Rm 303		3/31/12	Chicago sink drinker	100	24		x	filter installed		
Grant High School	Room 32		5/20/12	Haws sink drinker	32	10		x	filter installed		
Gray Middle School	Art Rm		2/7/12	Haws sink drinker	29	5		x	filter installed		
Grout Elementary School	Near Rm 106		2/11/12	Elkay single cooler		18		x	fixture replaced, filter installed 11/19/01		
Grout Elementary School	Near Rm 201 Left		2/7/12	Halsey Taylor double bubbler	29	38		x	filter installed		
Grout Elementary School	Near Rm 201 right (cen		2/11/12	Halsey Taylor double bubbler	24	3		x	filter installed		
Grout Elementary School	Near Rm 206 left		2/7/12	Halsey Taylor double bubbler	16	11		x	filter installed		
Grout Elementary School	Near Rm 206 Right		2/7/12	Halsey Taylor double bubbler	24	25		x	filter installed		
Grout Elementary School	Near Rm 208		2/4/12		28	4		x	filter installed		
Grout Elementary School	Near Rm A left double r		2/4/12		46			x	filter installed		
Grout Elementary School	Near Rm A right double		2/11/12	Halsey Taylor double bubbler		18		x	filter installed		
Grout Elementary School	Near Rm C Left double		2/7/12	Central double bubbler	24			x	filter installed		
Grout Elementary School	Near Rm C left double r		2/7/12		25			x	filter installed		
Grout Elementary School	Near Rm C right double		2/7/12	Halsey Taylor double bubbler	35	5		x	filter installed		
Grout Elementary School	Nr Rm A left double left		2/4/12		26			x	filter installed		
Grout Elementary School	Rm 112		2/7/12	Chicago sink drinker	5	23		x	filter installed		
Harrison Park School	Room 130		2/27/12	Central single bubbler	14	41		x	filter installed		
Hayhurst Elementary School	Rm 15		1/28/12		21	3		x	filter installed		
Jackson Middle School	Across from A108		7/15/12		45	58		x	filter installed		
Jackson Middle School	Near G east - mech		7/15/12	Central double bubbler	19	12		x		x	no filter - field verified
Jefferson High School	A11		6/22/12	chicago faucet	20	18		x	fixture replaced, filter installed 11/5/04		
Jefferson High School	A12		6/10/12	Faucet for drinking	10	34		x	filter installed		
Jefferson High School	A41		6/10/12	Central sink drinker	66	33		x	filter installed		
Jefferson High School	A42		6/10/12	Central sink drinker	18	3		x	filter installed		
Jefferson High School	Auto Shop		6/22/12	Elkay single cooler	37	39		x	filter installed		
Jefferson High School	Boys locker room (outs		6/22/12	Elkay single bubbler	26	26		x	filter installed		
Jefferson High School	Girls locker room (outs		6/22/12	Kohler single bubbler	64	57		x	filter installed		
Jefferson High School	Gym B floor west		6/10/12	Haws in-wall fountain	20	22		x	filter installed		
Jefferson High School	Gym North (the outside		6/22/12	elkay in-wall	18	11		x	filter installed		

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Jefferson High School	Near B23		6/10/12	Halsey Taylor double bubbler	64	40		x	filter installed		
Jefferson High School	Near D21		6/10/12	Haws double bubbler	48	21		x	filter installed		
Jefferson High School	Near D33		6/10/12	central double in wall	14	65		x	filter installed		
Jefferson High School	Near dance offices		6/10/12	Haws single bubbler	22	2		x	filter installed		
Jefferson High School	Near locker c376		6/10/12	Halsey Taylor double bubbler	65	14		x	filter installed		
Jefferson High School	Near TV studio		6/10/12	Haws single bubbler	150	140		x	filter installed		
Kelly Elementary School	Music rm, portable		1/16/12	Central single bubbler	174	32		x	filter installed		
Kelly Elementary School	Rm 25		1/16/12	sink (chicago brand)	32			x	kelly center - fixture removed, replumbed with plastic (field verified)		
Kelly Elementary School	Rm 7		2/15/12	Sink	34	0		x	Kelly Center - appears faucet has been replaced as has the plumbing (field verified)		
Kelly Elementary School	Rm 7 (Lounge)		1/16/12	Sink	140			x	Kelly Center - appears faucet has been replaced as has the plumbing (field verified)		
King Elementary School	Gym West		3/25/12	Central double bubbler	59	18		x	filter installed		
Markham Elementary School	Room 133		7/2/12	Standard single bubbler	54	56		x	filter installed		
Marshall High School	A22		6/25/12	Haws single bubbler	130	10		x	filter installed		
Marshall High School	A26		6/25/12	Haws single bubbler	24	3		x	filter installed		
Marshall High School	A4		6/25/12	Haws single bubbler	250	95		x	filter installed		
Marshall High School	A9		7/7/12	Haws single bubbler	49	17		x	filter installed		
Marshall High School	Boys locker room		6/27/12	Haws in-wall fountain	28	17		x	filter installed		
Marshall High School	East cafeteria		6/25/12	Haws in-wall fountain	17	5		x	filter installed		
Marshall High School	Girls locker room		6/27/12	Haws single bubbler	23	23		x	filter installed		
Marshall High School	Near B56		6/25/12	Chicago double bubbler		30		x	filter installed		
Marshall High School	Near B61		6/25/12	Haws single bubbler	30	27		x	filter installed		
Marshall High School	Wrestling room		6/27/12	In-wall fountain	48	35		x	filter installed		

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Peninsula Elementary School	Kitchen Food prep sink other		12/22/11		20			x		x	no filter - field verified
Ramona Headstart	134		7/8/12	Chicago sink drinker	6	18		x	filter installed		
Ramona Headstart	135		7/8/12	Chicago sink drinker	10	38		x	filter installed		
Ramona Headstart	Rm 157		7/8/12	Chicago sink drinker	11	39		x	filter installed		
Rice Site	Rm 3		7/5/12	Haws sink drinker	25	36		x	filter installed		
Rice Site	Rm 6		7/5/12	Haws sink drinker	25	47		x	filter installed		
Rice Site	Storeroom 1		7/5/12	Haws sink drinker	1700	250		x	filter installed		
Rieke Elementary School	Outside gym		12/21/11	Central single bubbler	16	18		x	filter installed		
Roosevelt High School	Boys locker room near		6/20/12		50	25		x	filter installed		
Roosevelt High School	Crib room		3/31/12	sink faucet	24	3		x	filter installed		
Roosevelt High School	Rm 128		3/31/12	Halsey Taylor single bubbler	19	16		x	filter installed		
Roosevelt High School	Rm 129		3/31/12	Central single bubbler	28	69		x	fixture replaced, filter installed		
Roosevelt High School	Room A180		5/28/12	Central double bubbler	17	26		x	filter installed		
Roosevelt High School	Room M149		5/28/12	Haws single bubbler	25	19		x	filter installed		
Roosevelt High School	Room M152		5/28/12	Haws single bubbler	23	17		x	filter installed		
Rosa Parks Elementary School	Near 115 left		7/4/12	Haws double bubbler	34	2		x	filter installed		
Rose City Park Elementary School	Room 1- Co	101	3/22/16	Sink fixture	27	18	x	x	sign posted		
Rose City Park Elementary School	Room 1- sir	1	3/22/16	Sink fixture	29	10	x	x	sign posted		
Rose City Park Elementary School	Room 1- sir	1	3/22/16	Sink fixture	30	30	x	x	sign posted		
Rose City Park Elementary School	Room 2	2	3/22/16	Sink fixture	26	21	x	x	sign posted		
Rose City Park Elementary School	Room 200	200	3/22/16	Chicago single bubbler	31		x	x	fixture replaced		
Rose City Park Elementary School	Room 207	207	3/22/16	Sink fixture	34	14	x	x	fixture replaced		
Rose City Park Elementary School	Room 3	3	3/22/16	Chicago single bubbler	22		x	x	fixture replaced		
Rose City Park Elementary School	Room 9	9	3/22/16	Sink fixture	22	6	x	x	fixture replaced		
Sabin Elementary School	220C		3/25/12	Central single bubbler	76	29		x	filter installed		
Sacajawea Head Start	Near Room 101		4/9/12	Elkay single bubbler	6	19		x	fixture replaced, filter installed (11/5/01)		
Scott Elementary School	Rm 101		3/25/12	Central single bubbler	17	10		x	filter installed		
Scott Elementary School	Rm 201		3/25/12	Elkay single bubbler	19	14		x	filter installed		
Scott Elementary School	Rm 202		3/25/12	Central single bubbler	89	34		x	filter installed		
Scott Elementary School	Rm 204		3/25/12	Central single bubbler	8	17		x	filter installed		
Scott Elementary School	Rm 301		3/25/12	Central single bubbler	19	4		x	filter installed		
Sellwood Middle School	Near 307 left		1/16/12	Double fountain	20			x	filter installed		
Sellwood Middle School	Near 320		1/16/12	Double fountain	10	18		x	filter installed		

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Sitton Elementary School	Near Library		4/8/12	Central single bubbler	16	1		x	filter installed		
Sitton Elementary School	Rm 15		7/1/12	Chicago sink drinker	33			x	filter installed		
Sitton Elementary School	Rm 16		7/1/12	Chicago sink drinker	21			x	filter installed		
Sitton Elementary School	Room 14		4/8/12	Chicago sink drinker	37			x	filter installed		
Sitton Elementary School	Room 4		4/8/12	Central single bubbler	39	7		x	filter installed		
Sitton Elementary School	Room 8		4/8/12	Standard single bubbler	8	23		x	filter installed		
Tubman Middle School	Near Rm 132C		3/17/12	Central sink drinker	38	14		x	filter installed		
Tubman Middle School	Rm 200 low flow		3/17/12	Central single bubbler	29	31		x	filter installed		
Tubman Middle School	Rm 206 low flow		3/17/12	Halsey Taylor single bubbler	20	17		x	filter installed		
Vernon Elementary School	Room 202		4/15/12	Crane single bubbler	130	0		x		x	no filter, same fixture - field verified
Whitman Elementary School	Near C1		2/5/12	Central single bubbler	14	18		x	filter installed		
Whitman Elementary School	Near Rm 12		2/11/12	haws single bubbler?	27	1		x	filter installed		
Whitman Elementary School	Near Rm 17		2/11/12	Haws single bubbler	18	4		x	filter installed		
Whitman Elementary School	Rm 1		2/5/12	Haws sink drinker	17	14		x	filter installed		
Whitman Elementary School	Rm 12		7/8/12	Haws sink drinker	27			x		x	no filter - field verified
Whitman Elementary School	Rm 20		7/8/12	Haws sink drinker	37	33		x	filter installed		
Whitman Elementary School	Rm 23		7/8/12	Haws sink drinker	36			x	filter installed		
Wilson High School	By Rm 245 Middle		12/1/11		19	30	x	x			
Woodmere Elementary School	Rm 24		1/7/12		35			x	filter installed		
Woodstock Elementary School	Near playcourt		2/5/12	Central double bubbler	46	34		x	filter installed		