

SCHOOL	Location	Room Number	Date	DESCRIPTION	Draw 1 Lead (ppb)	Draw 2 Lead (ppb)	Clearance Testing Done	Results Above 15 ppb?	Actions Taken	Above 15 ppb, no actions, no clearance	Field Notes (2016)
Applegate Elementary School	Room 12		5/20/12	Chicago sink drinker	18			x		x	no filter - field verified
Faubion Elementary School	Room Principal2		4/29/12	Halsey Taylor single bubbler	17	3		x		x	
Franklin High School	Rm 273		3/11/12	Thin faucet for water bottles	28	4		x		x	
Jackson Middle School	Near G east - mech		7/15/12	Central double bubbler	19	12		x		x	no filter - field verified
Peninsula Elementary School	Kitchen Food prep sink other		12/22/11		20			x		x	no filter - field verified
Vernon Elementary School	Room 202		4/15/12	Crane single bubbler	130	0		x		x	no filter, same fixture - field verified
Whitman Elementary School	Rm 12		7/8/12	Haws sink drinker	27			x		x	no filter - field verified